

# CORRECTION TO WATER WELL RECORD (WWC-5)

The following correction(s) was made to the attached WWC-5 log, in order to file the item or to rectify lacking or incorrect information.

Fraction ( 1/4 1/4 1/4) Section-Township-Range changed:

listed as Lake Lot 19, Plat 3, 20-22S-24E

changed to SW SW NW, 20-22S-24E

Other changes: Initial statements: \_\_\_\_\_

Changed to: \_\_\_\_\_

Comments: \_\_\_\_\_

verification method: Legal description, and plat map of Sugar Valley Lake  
from Linn County Appraiser. initials: DR date: 2/26/2002

submitted by: Kansas Geological Survey, Data Resources Library, 1930 Constant Ave., Lawrence, KS 66047-3726  
to: Kansas Dept of Health & Environment Bureau of Water Industrial Programs, Bldg 283, Forbes Field, KS 66620

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well: County <u>LINN</u>		Fraction <u>Lake lot 19</u> <u>Platt #3</u> 1/4 1/4 1/4	Section number <u>20</u>	Township number T <u>22</u> S	Range number R <u>24</u> <u>W</u>
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: <u>BILL NELSON</u> R.R. or street: <u>13217 W. 76th</u> City, state, zip code: <u>LENEXA KS. 66216</u>		
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile			Sketch map: <u>LAKE</u> <u>DRAINAGE</u> <u>WATER X WELL</u> <u>LAKE LOT #19</u> <u>PLATT #3</u> <u>ROAD</u>		
5. Type and color of material			From	To	6. Bore hole dia. <u>6.25</u> in. Completion date <u>8/28/78</u> Well depth <u>60</u> ft.
<u>Topsoil</u>			<u>0'</u>	<u>1'</u>	7. <u>X</u> Cable tool <u>X</u> Rotary <u>Air</u> Driven <u>  </u> Dug <u>  </u> <u>  </u> Hollow rod <u>  </u> Jetted <u>  </u> Bored <u>  </u> Reverse rotary
<u>LIME STONE / BROKEN</u>			<u>1'</u>	<u>5'</u>	8. Use: <u>X</u> Domestic <u>  </u> Public supply <u>  </u> Industry <u>  </u> <u>  </u> Irrigation <u>  </u> Air conditioning <u>  </u> Stock <u>  </u> <u>  </u> Lawn <u>  </u> Oil field water <u>  </u> Other <u>  </u>
<u>GRAY SHALE</u>			<u>5'</u>	<u>11'</u>	9. Casing: Material <u>PLASTIC</u> Height: <u>Above</u> or below Threaded <u>  </u> Welded <u>  </u> Surface <u>  </u> <u>1 1/2</u> in. RMP <u>  </u> PVC <u>X</u> Weight <u>  </u> lbs./ft. Dia. <u>5</u> in. to <u>60</u> ft. depth Wall Thickness: inches or Dia. <u>2 1/2</u> in. to <u>  </u> ft. depth gage No. <u>365</u>
<u>LIME STONE / CAP ROCK BLUE</u>			<u>11'</u>	<u>13'</u>	10. Screen: Manufacturer's name <u>VINYLPLEX</u> <u>TNE.</u> Type <u>PVC PLASTIC</u> Dia. <u>5" T.D.</u> Slot/gauze <u>1/2" (500)</u> Length <u>17</u> Set between <u>23</u> ft. and <u>40</u> ft. <u>  </u> ft. and <u>  </u> ft. Gravel pack? <u>NO</u> Size range of material <u>  </u>
<u>GRAY SHALE</u>			<u>13'</u>	<u>23'</u>	11. Static water level: <u>  </u> no./day/yr. <u>14</u> ft. below land surface Date <u>8/28/78</u>
<u>SANDSTONE, YELLOW/BROWN</u>			<u>23'</u>	<u>25'</u>	12. Pumping level below land surfaces: <u>  </u> ft. after <u>  </u> hrs. pumping <u>  </u> g.p.m. <u>  </u> ft. after <u>  </u> hrs. pumping <u>  </u> g.p.m. Estimated maximum yield <u>  </u> g.p.m.
<u>GRAY SHALE w/ F-SAND</u>			<u>25'</u>	<u>36'</u>	13. Water sample submitted: <u>  </u> no./day/yr. <u>X</u> Yes <u>  </u> No Date <u>5-7-79</u>
<u>LIME STONE, BROKEN w/ F-SAND</u>			<u>36'</u>	<u>38'</u>	14. Well head completion: <u>  </u> Pitless adapter <u>  </u> inches above grade
<u>GRAY SHALE</u>			<u>38'</u>	<u>51'</u>	15. Well grouted? <u>NO</u> <u>yes</u> With: <u>X</u> Neat cement <u>  </u> Bentonite <u>X</u> Concrete Depth: From <u>0</u> ft. to <u>11</u> ft.
<u>LIME STONE</u>			<u>51'</u>	<u>57'</u>	16. Nearest source of possible contamination: <u>NONE</u> ft. <u>  </u> Direction <u>  </u> Type <u>  </u> Well disinfected upon completion? <u>X</u> Yes <u>  </u> No
<u>GRAY SHALE</u>			<u>57'</u>	<u>60'</u>	17. Pump: <u>X</u> Not installed Manufacturer's name <u>WATKINS SEARS</u> Model number <u>4271111 1 1/2</u> Volts <u>220</u> Length of drop pipe <u>50</u> ft. capacity <u>29</u> g.p.m. Type: <u>X</u> Submersible <u>  </u> Turbine <u>  </u> Jet <u>  </u> Reciprocating <u>  </u> Centrifugal <u>  </u> Other
(Use a second sheet if needed)					
18. Elevation:	19. Remarks: <u>Has NOT yet Completed well + DOES</u> <u>NOT KNOW WHAT TYPE OF PUMP TO PUMPS</u> <u>GET OR SUBMERSIBLE TO USE</u> <u>VERY FINE PRODUCING WATER WELL</u>		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>380</u> <u>THOMAS L NORRIS DRILLING</u> Business name License No. <u>  </u> Address <u>1111 S. MARYGARDEN, FT. SCOTT</u> Signed <u>Thomas L Norris</u> Date <u>4/8/79</u> Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5