

Sept 4-8-77

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Marion	Fraction NE 1/4 NE 1/4 NW 1/4	Section number 16	Township number T 22 S R 3 EW	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: R.R. or street: City, state, zip code:			
2. Distance and direction from nearest town or city: 1 mile south and 1/2 west of Peabody			3. Owner of well: Alice Litton R.R. or street: RR #2 City, state, zip code: Peabody, Kansas			
4. Locate with "X" in section below:		Sketch map: road			6. Bore hole dia. 10 in. Completion date Well depth 78 ft. 3/1/77	
					7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material plastic Height Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12" in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 228 lbs./ft. Dia. 5 in. to 25 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 225		
Loam		0	5	10. Screen: Manufacturer's name Robin-Tech - own slot Type PVC Dia. 5" Slot/gauze .046 Length 20' Set between 40 ft. and 60 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8-1/4		
" to brown clay		5	10	11. Static water level: 32 ft. below land surface Date 3/2/77		
brown clay to gray		10	13	12. Pumping level below land surfaces: 72 ft. after 2 hrs. pumping 12 g.p.m. ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 12 g.p.m.		
light gray shale		13	16	13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date _____		
light gray clay - semi hard		16	30	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
soft gray clay		30	48	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 10 ft. to 0 ft.		
brown semi-hard rock - layers		48	51	16. Nearest source of possible contamination: ft. 72 Direction East Type Sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
gray clay		53	64	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
dark brown rock - hard!		64	66	18. Elevation:		
dark "Wellington" shale - hard		66	75	19. Remarks: water out of fissures & layers in brown rock -		
(Use a second sheet if needed)				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Paul's Inc #125 Business name _____ License No. _____ Address Box 26 Hesston, KS Signed Paul's Inc Date 3/2/77 Authorized representative		

22 - 30 W 16 NE NE NW
 T R S W Sec 1/4 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5