


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

Lot 15 CL

1 Location of well:	County CHASE	Township name	Fraction SENE SW	Section number 7	Town number 225	Range number 8E
Distance and direction from nearest town or city: 1/2 mi South K 177 Mattfield Green				3 Owner of well: Arnie Evenson Address: Cottonwood Falls KS 66845		
Locate with "X" in section below: 				Sketch map:		
2				4 Well depth: 66 ft. Date of completion 1/18 Well diameter 8 in. 76		
Type and color of material				5 <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
From To				6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
Ts Dk Bnn				7 Casing: Material Steel Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 36 in. Diam. 6 in. to 66 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No 6 in. to 66 ft. depth		
Broken Lime & shale Gray & Bnn				8 Screen: SUNFLOWER Manufacturer Shop Slot Perc Type RMP Dia. 6" Slot gauge 1/8 x 6" Length 5 1/2 ft. Set between 15 ft. and 66 ft. Fittings: Gravel pack <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Size range of material		
Calc Sh Gray with some Gyp and				9 Static water level: 22 ft. below land surface Date 1/15/76		
A Few Lime Lens to 5 Thick mostly				10 Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 2-3 g.p.m.		
Very Soft				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
				12 Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 12 ft.		
				14 Nearest source of possible contamination: ft. 50 Direction South Type Ditch Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(use a second sheet if needed)						
16 Remarks: elevation Checked H2O Table Jan 10-1977 Measured @ 32' from G.L.				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. MENEE Drilling 203 Business name License No. Address Cottonwood Falls KS Signed [Signature] Date 1/18/76 Authorized representative		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5