

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County HARVEY	Fraction NW 1/4 SE 1/4 NE 1/4	Section number 9	Township number T 23	Range number S R 1 E
2. Distance and direction from nearest town or city: Street address of well location if in city:		1/4 MI N, 1 1/2 MI S from Newton		3. Owner of well: Rowland Funk R.R. or street: RR-2 City, state, zip code: NEWTON - KANSAS 67114		
4. Locate with "X" in section below: Sketch map:				6. Bore hole dia. 4 1/2 in. Completion date 5-13-78 Well depth 42 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material ASTM Height Above ground 30 MHS Threaded <input type="checkbox"/> Welded COOL Surface 78 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 42 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. TYPE 200		
				10. Screen: Manufacturer's name SUNFLOWER PLASTIC PIPE Type 200 Dia. 5 1/2 30/ gauge <input type="checkbox"/> Length 20 Set between 20 ft. and 42 ft. <input type="checkbox"/> Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8 - 3/4		
				11. Static water level: 20 ft. below land surface Date 5-1-78		
				12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.		
				13. Water sample submitted: ____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date ____		
				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 inches above grade		
				15. Well grouted? YES With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.		
				16. Nearest source of possible contamination: ft. 350 Direction SW Type SEWAGE Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: Not installed Manufacturer's name GOULD Model number DE-512 HP 1/2 Volts 230 Length of drop pipe 40 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. MARTIN SCORPY 362 Business name License No. Address 500 W 3RD N-NEWTON Signed Butch Schmidt Date 5/20 Authorized Representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

23-10-5
1/4 1/4 1/4
MAYSEN