

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215


Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well: County HARVEY Township name Newton Fraction SW 1/4 / SE 1/4 Section number 145 Town number T-23-S Range number R-1-E

Distance and direction from nearest town or city: _____ 3 Owner of well: HAROLD GROSS

Street address of well location if in city: E 24th St. Address: E 24th St. N. Newton, KAN

Locate with "X" in section below: Sketch map: N



4 Well depth: 39 ft. Date of completion 5/22/75
Well diameter 12" in.

5 Cable tool Rotary Driven Dug
 Hollow rod Jetted Bored Reverse rotary

6 Use: Domestic Public supply Industry
ya Irrigation Air conditioning Commercial
 Test well

7 Casing: Material PVC Height: above/below
Threaded Welded Surface 18 in.
Diam. 6" Weight 3.22 lbs./ft.
+ 18 in. to 39 ft. depth Drive shoe? Yes No
_____ in. to _____ ft. depth!

2	Type and color of material	From	To
	<u>Loam</u>	<u>0</u>	<u>5</u>
	<u>11 to light br. clay</u>	<u>5</u>	<u>12</u>
	<u>Sand - med size</u>	<u>12</u>	<u>15</u>
	<u>Sand coarse</u>	<u>15</u>	<u>22</u>
	<u>grey-green shale</u>	<u>22</u>	<u>25</u>
	<u>light grey shale</u>	<u>25</u>	<u>30</u>
	<u>dark blk shale</u>	<u>30</u>	<u>39</u>
	<u>White Limer Stone</u>	<u>39</u>	

8 Screen: pip man - cent feed
Manufacturer OWN slot
Type _____ Dia. 6"
Slot/gauze 246 Length 10'
Set between 14 ft. and 24 ft.
Fittings: 1/8-3/8"
Gravel pack Yes No Size range of material _____

9 Static water level:
9 ft. below land surface Date 5/22/75

10 Pumping level below land surfaces:
18 ft. after 1 hrs. pumping 20 g.p.m.
_____ ft. after _____ hrs. pumping _____ g.p.m.
Estimated maximum yield 20 g.p.m.

11 Water sample submitted:
 Yes No Date _____

12 Well head completion:
 Pitless adapter Inches above grade

13 Well grouted? Yes No
 Neat cement Bentonite _____
Depth: From 0 ft. to 10 ft.

14 Nearest source of possible contamination:
ft. 63 Direction North Type house sewer
Well disinfected upon completion? Yes No

15 Pump:
 Not installed
Manufacturer's name Aermator
Model number 1/2 HP SD-12-50 volts 230
Length of drop pipe 35 ft. capacity 12 g.m.p.
Type:
 Submersible Turbine
 Jet Reciprocating
 Centrifugal Other

16 Remarks: elevation

Topography:
 Hill
 Slope
 Upland
 Valley

17 Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
PAUL'S INC #175
Business name _____ License No. _____
Address Box 26 Hesstank, Kan
Signed Paul Brambitt Date 5/22/75
Authorized representative