

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County HARVEY	Fraction SE 1/4 SE 1/4 SW 1/4	Section number 7	Township number T 23 S R 1	Range number 1
2. Distance and direction from nearest town or city: Street address of well location if in city: SAME			3. Owner of well: JAMES ZOOK R.R. or street: 1401 GRAND VIEW City, state, zip code: Newton, Kans		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 11 in. Completion date _____ Well depth 48 ft. 6/31/77	
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material plastic height: (Above or below) _____ Threaded _____ Welded <input checked="" type="checkbox"/> Surface 12 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 48 ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth gage No. 2258	
Loom to clay		0	5	10. Screen: Manufacturer's name _____ Robin-Tech - own Slot	
red brown clay		5	12	Type PVC Dia. 5"	
Sandy brown clay		12	23	Slot/gauze 4/6 Length 20	
Sand + clay mix		23	25	Set between 45 ft. and 25 ft.	
Sand med		25	28	_____ ft. and _____ ft.	
Sandy clay - gray		28	45	Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8-1/4	
course sand + clay mix		43	45	11. Static water level: _____ mo./day/yr. 15 1/2 ft. below land surface Date 7/19/77	
dark gray shale		45	48	12. Pumping level below land surfaces: 37 ft. after 2 hrs. pumping 15 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 15-25 g.p.m.	
				13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No _____ Date _____	
				14. Well head completion: _____ Pitless adapter 12 Inches above grade	
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____ Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: house ft. 46 Direction EAST Type sewer Well disinfected upon completion? _____ Yes <input checked="" type="checkbox"/> No _____	
				17. Pump: _____ Not installed Manufacturer's name Wolley Model number S-1208 HP 1/3 Volt: 230 Length of drop pipe 45 ft. capacity 12 g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine <input type="checkbox"/> Jet _____ Reciprocating <input type="checkbox"/> Centrifugal _____ Other _____	
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. PAUL'S INC #175 Business name _____ License No. _____ Address Box 26 Hesston, Kans Signed Paul Brubaker Date 8/1/77 Authorized representative	

23-10-7
 Sec 7 SE SE SW
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5