

LOCATION OF WATER WELL
 County: HARVEY Fraction SW $\frac{1}{4}$ NW $\frac{1}{4}$ SW $\frac{1}{4}$ Section Number 17 Township Number 23 Range Number 1 EW
 Distance and direction from nearest town or city? NEWTON Street address of well if located within city? 122 E. 1st

WATER WELL OWNER: Rudolph B. ENNS
 RR#, St. Address, Box #: 122 E. 1st St. NEWTON, MO. 67114 Board of Agriculture, Division of Water Resources
 City, State, ZIP Code: Application Number:

DEPTH OF COMPLETED WELL: 52 ft. Bore Hole Diameter: 5" in. to 30 ft. and 4 1/2 in. to 52 ft.
 Well Water to be used as:
 1 Domestic 3 Feedlot 6 Oil field water supply 8 Air conditioning 11 Injection well
 2 Irrigation 4 Industrial 7 Lawn and garden only 9 Dewatering 12 Other (Specify below)
 10 Observation well
 Well's static water level: 19 ft. below land surface measured on May month 30 day 1980 year
 Pump Test Data: Well water was 22 ft. after 10 hours pumping 3 gpm
 Est. Yield 5 gpm: Well water was dry ft. after 2 hours pumping 6 gpm

TYPE OF BLANK CASING USED:
 1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile Casing Joints: Glued X Clamped
2 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded
 7 Fiberglass Threaded
 Blank casing dia: 2 in. to 4 7/8 in. Dia 2 SCREEN to 52 ft. Dia in. to ft.
 Casing height above land surface: 13" in. weight lbs./ft. Wall thickness or gauge No.

TYPE OF SCREEN OR PERFORATION MATERIAL:
 1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 10 Asbestos-cement
 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 12 None used (open hole)
 Screen or Perforation Openings Are:
 1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole)
 2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes
 7 Torch cut 10 Other (specify) Polypropylene SCREEN
 Screen-Perforation Dia: in. to ft. Dia 2 in. to 5 ft. Dia in. to ft.
 Screen-Perforated Intervals: From ft. to ft. From ft. to ft. From ft. to ft.
 Gravel Pack Intervals: From 10 ft. to 52 ft. From ft. to ft. From ft. to ft.

GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other
 Grouted Intervals: From Top ft. to 10 ft. From ft. to ft. From ft. to ft.
 What is the nearest source of possible contamination:
 1 Septic tank 4 Cess pool 7 Sewage lagoon 10 Fuel storage 14 Abandoned water well
 2 Sewer lines 5 Seepage pit 8 Feed yard 11 Fertilizer storage 15 Oil well/Gas well
 3 Lateral lines 6 Pit privy 9 Livestock pens 13 Watertight sewer lines 16 Other (specify below)
 Direction from well: NW How many feet: 40 ? Water Well Disinfected? Yes No
 Was a chemical/bacteriological sample submitted to Department? Yes No If yes, date sample was submitted month day year: Pump Installed? Yes No
 If Yes: Pump Manufacturer's name: SEARS Roebuck Model No. 390-25110 HP 1/2 Volts 110
 Depth of Pump Intake: 44 ft. Pumps Capacity rated at 6 @ 30# and 1 lb. at 50# gal./min.
 Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other

CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed (2) reconstructed, or (3) plugged under my jurisdiction and was completed on JUNE month 16th day 1980 year
 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 390
 This Water Well Record was completed on JUNE month 20 day 1980 year under the business name of Home Water Well Drilling & Supply (signature) Rudolph B. Enns

LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:	FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG
	0	4	BLACK DIRT			
	4	19	CLAY			
	19	25	SHALE			
	25	38	CLAY + ROCK			
	38	41	SHALE + SAND			
	41	52	ROCK + CLAY			

ELEVATION: Depth(s) Groundwater Encountered 1. 18 ft. 2. 38 ft. 3. ft. 4. ft. (Use a second sheet if needed)

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.

OFFICE USE ONLY
R
EW
SEC
17
SW 1/4 NW 1/4 SW 1/4