


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

2017 5-12-76

1. Location of well:	County HARVEY	Fraction SE 1/4 SE 1/4 NW 1/4	Section number 18	Township number T 23 S R 1 EW	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city: 2019 Ida Lane, Newton			3. Owner of well: Victor Junk R.R. or street: 2019 Ida Lane City, state, zip code: Newton Kansas		
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. 7 1/2 in. Completion date March 29 Well depth 75 ft. 3-29-76		
5. Type and color of material			7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
From To			9. Casing: Material Plastic Height (Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 2 1/4 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 200 lbs./ft. Dia. 5 in. to 75 ft. depth; Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth; gage No. 4		
			10. Screen: Manufacturer's name Sunflower Plastic Pipe Inc Type Plastic Dia. 5 Slot/gauze 3/32 Length 2 in Set between 20+40 ft. and 50+70 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 20 to 30 ft.		
Block Soil			11. Static water level: <input type="checkbox"/> mo./day/yr. 20 ft. below land surface Date March 29		
Clay			12. Pumping level below land surfaces: 35 ft. after 1 hrs. pumping 12 g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 15 g.p.m.		
Sandy Loam			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date _____		
Sand			14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade		
Blue Slate			15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Limestone			16. Nearest source of possible contamination: C.I. ft. 15 Direction N Type Sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Blue Shale			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Terah Buddle 221 Business name _____ License No. _____ Address Newton Kansas Signed Terah Buddle Date April 1/4 Authorized representative		
18. Elevation:		19. Remarks:			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5