

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County HARVEY	Fraction SE 1/4 NW 1/4 NE 1/4	Section number 18	Township number T 23 S	Range number R 1 E
2. Distance and direction from nearest town or city: Street address of well location if in city: SAME			3. Owner of well: VERNON MEGLI R.R. or street: 921 Grandview City, state, zip code: Newton, Kansas			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 12 in. Completion date 3/25/77 Well depth 33 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Loam		0	5	9. Casing: Material plastic Height Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12" in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 3.23 lbs./ft. Dia. 6 in. to 33 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 0.255		
Red-brown clay		5	10	10. Screen: Manufacturer's name Robin-Tech - own slot Type pvc Dia. 6 Slot/gauze 1046 Length 20' Set between 23 ft. and 33 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 18-14		
Red clay		10	15	11. Static water level: 18 1/2 ft. below land surface Date 3/25/77		
SANDY clay		15	20	12. Pumping level below land surfaces: 30 ft. after 2 hrs. pumping 15 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 15 (MAX) g.p.m.		
Sand - med course - some clay		20	29	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
green-grey shale		29	30	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
dark to black shale		30	33	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 10 ft. to 0 ft.		
				16. Nearest source of possible contamination: house ft. 37 Direction South Type sewer line Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Dempster Model number OM-33 HP 1/3 Volts 230 Length of drop pipe 30 ft. capacity 15 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. PAULS INC #175 Business name License No. Address Box 26 Hesston, Kansas Signed Paul Pauls Date 3/25/77 Authorized representative		
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5