

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

<input checked="" type="checkbox"/> Location of well:	County HARVEY	Fraction SW 1/4 SW 1/4 SW 1/4	Section number 19	Township number T 23 S R 1 E W	Range number
<input checked="" type="checkbox"/> Distance and direction from nearest town or city:	Street address of well location if in city: 304 SW 9th		3. Owner of well: F.E. MITCHELL R.R. or street: 304 SW 9th City, state, zip code: NEWTON KS 67114		
<input checked="" type="checkbox"/> Locate with "X" in section below:	Sketch map: 		6. Bore hole dia. 10 in. Completion date 7-30-77 Well depth 52 ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material PITS Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 1.50 lbs./ft. Dia. 5 in. to 52 ft. depth; Wall Thickness, inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth; gage No. 202		
			10. Screen: Manufacturer's name J & J Type RMP Dia. 5 Slot/gauze .06 Length 30 Set between 20 ft. and 50 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 44-38		
			11. Static water level: <input type="checkbox"/> mo./day/yr. 20 ft. below land surface Date 7-30-77		
			12. Pumping level below land surfaces: 30 ft. after 1 hrs. pumping 10 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 10 g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>		
			14. Well head completion: NO Pitless adapter 18 inches above grade		
			15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: ft. 30 Direction W Type SEWER Well disinfected upon completion? yes Yes <input type="checkbox"/> No <input type="checkbox"/>		
			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name RED JACKET Model number <input type="checkbox"/> HP 1/3 Volts 230 Length of drop pipe 45 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
			(Use a second sheet if needed)		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. DYOR Well Service 211 Business name License No. Address 428 W 3rd Newton KS Signed DYOR Well Service Date 8-24-77 Authorized representative	
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

T 23
 R 1
 W E
 Sec 19
 S W
 1/4 1/4 1/4