

1 LOCATION OF WATER WELL		Fraction	Section Number	Township Number	Range Number
County: HARVEY		NE 1/4 SW 1/4 NW 1/4	21	T 23 S	R 1 EW
Distance and direction from nearest town or city? SAME			Street address of well if located within city? 931 SE 5th, NEWTON		

2 WATER WELL OWNER: PAUL KOERPERICH		Board of Agriculture, Division of Water Resources
RR#, St. Address, Box #: Box 285		Application Number: 67114
City, State, ZIP Code: NEWTON, KANSAS		

3 DEPTH OF COMPLETED WELL: 90 ft. Bore Hole Diameter: 11 in. to 90 ft., and 90 in. to 90 ft.	
Well Water to be used as:	
1 Domestic	3 Feedlot
2 Irrigation	4 Industrial
5 Public water supply	
6 Oil field water supply	
7 Lawn and garden only	
8 Air conditioning	
9 Dewatering	
10 Observation well	
11 Injection well	
12 Other (Specify below)	
Well's static water level: 6' ft. below land surface measured on 4 month 23 day 1980 year	
Pump Test Data: Well water was 90 ft. after 2 hours pumping 6 gpm	
Est. Yield 6 gpm: Well water was 90 ft. after 2 hours pumping 6 gpm	

4 TYPE OF BLANK CASING USED:		5 Wrought iron	8 Concrete tile	Casing Joints: Glued X Clamped
1 Steel	3 RMP (SR)	6 Asbestos-Cement	9 Other (specify below)	Welded
2 PVC	4 ABS	7 Fiberglass		Threaded
Blank casing dia 5' in. to 90 ft., Dia 90 in. to 90 ft., Dia 90 in. to 90 ft.				
Casing height above land surface: 18 in., weight 2.83 lbs./ft. Wall thickness or gauge No 259				
TYPE OF SCREEN OR PERFORATION MATERIAL:		10 Asbestos-cement		
1 Steel	3 Stainless steel	5 Fiberglass	8 RMP (SR)	11 Other (specify)
2 Brass	4 Galvanized steel	6 Concrete tile	9 ABS	12 None used (open hole)
Screen or Perforation Openings Are:		5 Gauzed wrapped	8 Saw cut	11 None (open hole)
1 Continuous slot	3 Mill slot	6 Wire wrapped	9 Drilled holes	
2 Louvered shutter	4 Key punched	7 Torch cut	10 Other (specify)	
Screen-Perforation Dia 5 in. to 90 ft., Dia 90 in. to 90 ft., Dia 90 in. to 90 ft.				
Screen-Perforated Intervals: From 10 ft. to 30 ft., From 50 ft. to 90 ft.				
Gravel Pack Intervals: From 10 ft. to 90 ft., From 50 ft. to 90 ft.				

5 GROUT MATERIAL:		1 Neat cement	2 Cement grout	3 Bentonite	4 Other
Grouted Intervals: From 8 ft. to 0 ft., From 0 ft. to 0 ft., From 0 ft. to 0 ft., From 0 ft. to 0 ft.					
What is the nearest source of possible contamination:		10 Fuel storage	14 Abandoned water well		
1 Septic tank	4 Cess pool	7 Sewage lagoon	11 Fertilizer storage	15 Oil well/Gas well	
2 Sewer lines	5 Seepage pit	8 Feed yard	12 Insecticide storage	16 Other (specify below)	
3 Lateral lines	6 Pit privy	9 Livestock pens	13 Watertight sewer lines		
Direction from well: EAST How many feet 50' plus ? Water Well Disinfected? Yes X No					
Was a chemical/bacteriological sample submitted to Department? Yes No If yes, date sample					
was submitted month day year Pump Installed? Yes No					
If Yes: Pump Manufacturer's name Model No. HP Volts					
Depth of Pump Intake ft. Pumps Capacity rated at gal./min.					
Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other					

6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on 4 month 23 day 80 year	
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 175	
This Water Well Record was completed on 4 month 25 day 80 year under the business name of PAUL'S INC by (signature) Paul Brinkman	

7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:	FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG
	0	2	top soil	75	90	DRK SHALE
	2	6	SANDY CLAY			
	6	8	SAND GRAVEL			
	8	12	GRN. SHALE			
	12	20	GRY SHALE			
	30	45	11 to DRK SHALE			
	45	55	DRK SHALE			
	55	58	HARD WHT (CAL.) LAYER			
	58	65	DRK SHALE			
	65	70	Soft DRK SHALE			
	70	75	DRK SHALE w/ crystals			

ELEVATION:		Depth(s) Groundwater Encountered 1. 6' ft. 2. 53 ft. 3. ft. 4. ft.		(Use a second sheet if needed)
------------	--	--	--	--------------------------------

OFFICE USE ONLY

T

R

SEC.

21

NE 1/4

SW 1/4

SE 1/4

NW 1/4