


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County HARVEY	Fraction NW 1/4 NW 1/4 NE 1/4	Section number 26	Township number T 23-S	Range number R 1-E	E/W
2. Distance and direction from nearest town or city: 1st + SPENCER 1 E 1 S. 1/2 E Street address of well location if in city:			3. Owner of well: Gordon Stucky R.R. or street: R7D#3 City, state, zip code: Newton, Kansas 67114			
4. Locate with "X" in section below: 			6. Bore hole dia. 8 in. Completion date 12-14-78 Well depth 59 ft.			
5. Type and color of material			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
			9. Casing: Material Plastic Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18" in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 39 lbs./ft. Dia. 5 in. to 39 ft. depth Wall Thickness: inches or Dia. 5 in. to 39 ft. depth Gage No. 200			
			10. Screen: Manufacturer's name Sunflower Plastic Pipe Type 200 Dia. 5" Slot/gauze Slot 1/16 Length 20' Set between 39 ft. and 59 ft. Gravel pack? Yes Size range of material 1/8 - 1/4			
			11. Static water level: 14 ft. below land surface Date 12-14-78 12. Pumping level below land surfaces: 20 ft. after 15 hrs. pumping 14 g.p.m. 30 ft. after 30 hrs. pumping 25 g.p.m. Estimated maximum yield 25 g.p.m.			
(Use a second sheet if needed)			13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date			
			14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18" inches above grade			
			15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.			
			16. Nearest source of possible contamination: HGS BARN ft. 200 Direction EAST Type HGS BARN Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
			17. Pump: Not installed Manufacturer's name Gordon Stucky Model number DET 1410 3/4 Volts 230 Length of drop pipe 50 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Martin Supply 362 Business name License No. Address 500 West 22nd N. Newton, KS Signed B. J. Smith Date 12-14-78			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5