

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County COFFEY		Fraction SW 1/4 SW 1/4	Section number 8	Township number T 23 S	Range number R 17 E
2. Distance and direction from nearest town or city: 3 MI E I.S.		3. Owner of well: GREG GLEUE			
Street address of well location if in city: BE AND I.S. Hwy		R.R. or street: _____			
		City, state, zip code: BEROY KAN.			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 9 in. Completion date 6/29/78	
				Well depth 60 ft.	
				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
5. Type and color of material		From	To	9. Casing: Material PITS Height: Above or below	
BLACK SOIL		0	4	Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 24 in.	
YELLOW CLAY		4	10	RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 1280 lbs./ft.	
LITE YELLOW CLAY		10	26	Dia. 6 in. to 60 ft. depth Wall Thickness: inches or	
SANDY SOAP STONE		20	31	Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 280 or 1/4"	
GRAVEL RED		31	34	10. Screen: Manufacturer's name JESS	
GRAY SHALE		34	60	Type PVC Dia. 6	
				Slot/gauze 1/16 Length 20	
				Set between 30 ft. and 40 ft.	
				ft. and _____ ft.	
				Gravel pack? YES Size range of material 1/4	
				11. Static water level: _____ mo./day/yr.	
				30 ft. below land surface Date 6/28/78	
				12. Pumping level below land surfaces:	
				_____ ft. after _____ hrs. pumping _____ g.p.m.	
				_____ ft. after _____ hrs. pumping _____ g.p.m.	
				Estimated maximum yield 80 g.p.m.	
				13. Water sample submitted: _____ mo./day/yr.	
				Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____	
				14. Well head completion:	
				_____ Pitless adapter 24 inches above grade	
				15. Well grouted? <input checked="" type="checkbox"/>	
				With: _____ Neat cement _____ Bentonite <input checked="" type="checkbox"/> Concrete	
				Depth: From 0 ft. to 15 ft.	
				16. Nearest source of possible contamination: SEPTIC	
				ft. 300 Direction EAST Type TANK	
				Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed	
				Manufacturer's name _____	
				Model number _____ HP _____ Volts _____	
				Length of drop pipe _____ ft. capacity _____ g.p.m.	
				Type:	
				<input type="checkbox"/> Submersible <input type="checkbox"/> Turbine	
				<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating	
				<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)					
18. Elevation:	19. Remarks: MR GLEUE RAN HIS OWN PUMP		20. Water well contractor's certification:		
Topography:			This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. 312		
<input checked="" type="checkbox"/> Hill			LUMMINGS WELL SERV		
<input checked="" type="checkbox"/> Slope			Business name _____ License No. _____		
<input type="checkbox"/> Upland			Address TOPO NTD KAN		
<input type="checkbox"/> Valley			Signed Alan Cummings Date 7/10/78		
			Authorized representative		

T 23 S R 17 E Sec 8-1/2 SW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5