

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: <u>1</u>	County <u>Harrison</u>	Fraction <u>S 1/2 NE 1/4 SE 1/4</u>	Section number <u>18</u>	Township number <u>T 23</u>	Range number <u>S 2 R 2</u>	<u>QAW</u>
2. Distance and direction from nearest town or city: <u>5 E off Newton on 18th Street</u>			3. Owner of well: <u>Albert Buehle</u> R.R. or street: <u>R 3 Newton</u> City, state, zip code:			
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map:		6. Bore hole dia <u>7 1/2</u> in. Completion date <u>Aug 22 76</u> Well depth <u>71</u> ft.	
			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
			9. Casing: Material <u>Steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>18</u> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <u>200</u> lbs./ft. Dia. <u>5</u> in. to <u>7 1/2</u> ft. depth Wall Thickness: inches or Dia. <u>5</u> in. to <u>7 1/2</u> ft. depth gage No. <u>2110 dm</u>		10. Screen: Manufacturer's name <u>Sunflow Plastic 1/4 in.</u> Type <u>RMP</u> Dia. <u>3</u> Slot/gauze <u>3/32</u> Length <u>20</u> Set between <u>45</u> ft. and <u>65</u> ft. ft. and ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/4 in.</u>	
			11. Static water level: <u>30</u> ft. below land surface Date <u>Aug 22 76</u>		12. Pumping level below land surfaces: <u>30</u> ft. after <u>40</u> hrs. pumping <u>10</u> g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield <u>15</u> g.p.m.	
			13. Water sample submitted: <u>X</u> Yes <u>No</u> Date <u>Aug 22 76</u>		14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u>18</u> inches above grade	
			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		16. Nearest source of possible contamination: ft. <u>300</u> Direction <u>N</u> Type <u>pond</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
(Use a second sheet if needed)			17. Pump: <u>Not installed</u> Manufacturer's name <u>Gould</u> Model number <u>3</u> HP <u>3</u> Volts <u>115</u> Length of drop pipe <u>65</u> ft. capacity <u>7</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Frank Buehle</u> <u>221</u> Business name <u>Newton R 4</u> License No. Address <u>Newton R 4</u> Signed <u>Frank Buehle</u> Date <u>Aug 22 76</u> Authorized representative	
			18. Elevation:		19. Remarks:	
			Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley			

23 - 20 18 S 1/4 SE SE
 Sec 1/4 1/4