


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County HARVEY	Fraction NW 1/4 SE 1/4 SE 1/4	Section number 34	Township number T 23	Range number S R 20 2-E 0 W
X Distance and direction from nearest town or city: 2E & 3S Street address of well location if in city: 2N-2 1/2 W. of Whitewater			3. Owner of well: Melvin Klaassen R.R. or street: Rt 2 City, state, zip code: Whitewater, Kansas			
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. 8.0 in. Completion date 5-29-78 Well depth 75 ft.			
5. Type and color of material			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
CLAY - HARD BLUE SHALE - MEDIUM TO HARD HARD SHALE + GYPSUM ROCK			9. Casing: Material RST Height: Above or below Threaded <input type="checkbox"/> Welded BLUE Surface 24 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 75 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. 200			
			10. Screens: Manufacturer's name SEAFLOWER PLASTIC PIPE Type 200 Dia. 5 Slot gauge <input type="checkbox"/> Length 20 Set between 55 ft. and 75 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2 - 3/8			
			11. Static water level: <input type="checkbox"/> mo./day/yr. 35 ft. below land surface Date 5-31-78			
			12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.			
			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>			
			14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 14 inches above grade			
			15. Well grouted? YES With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 3 ft. to 14 ft.			
			16. Nearest source of possible contamination: ft. 150 Direction SE Type SEWAGE Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name GEOLOG Model number DEFS-12 HP 1/2 Volts 230 Length of drop pipe 60 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Martin Supply 362 Business name License No. Address 500 West 22nd N. Newton, Kan. Signed Butch Schmit Date 6-2-78 Authorized Representative			
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						