


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County BUTLER	Fraction SW 1/4 SW 1/4 SW 1/4	Section number 28	Township number T 23-S	Range number R 3-E	E/W
2. Distance and direction from nearest town or city: 1/2 M EAST 2 M SOUTH FROM ELBING				3. Owner of well: W. F. Wiebe R.R. or street: RR #1 BOX 69 City, state, zip code: Whitewater, Kansas 67154			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date 4-23-79 Well depth 79 ft.			
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
5. Type and color of material		From To		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
CLAY		0 25		9. Casing: Material Plastic Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Glue <input type="checkbox"/> Surface 24 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 59 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 200			
LIME STONE		25 35		10. Screen: Manufacturer's name Sunflower Plastic Pipe Type 200 Dia. 5" Slot/gauze 5/16" Length 20' Set between 59 ft. and 79 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft.			
BLUE SHALE		35 65		Gravel pack? Yes Size range of material 1/4-1/2			
CLAY - GRAY		65 75		11. Static water level: 12 ft. below land surface Date 4-23-79 mo./day/yr.			
SHALE - BLUE		75 79		12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 10 g.p.m.			
				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____			
				14. Well head completion: <input type="checkbox"/> Pitless adapter 24' Inches above grade			
				15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 15 ft.			
				16. Nearest source of possible contamination: ft. 100 Direction E Type LAKON Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Martin Supply 362 Business name _____ License No. _____ Address 500 West 2nd St. Newton, KS Signed Bruce Schmidt Date 4-23-79 Authorized representative			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5