

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

**23 7E 20 CMAA**  
T R EW sec 1/4 1/4 No.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620


1 Location of well:	County <b>Butler</b>	Township name <b>Sycamore</b>	Fraction <b>N-E 1/4</b>	Section number <b>20</b>	Town number <b>235</b>	Range number <b>7E</b>
---------------------	-------------------------	----------------------------------	----------------------------	-----------------------------	---------------------------	---------------------------

Distance and direction from nearest town or city: **2 Miles west Cassoday Kansas South side road**  
Street address of well location if in city:

3 Owner of well: **Mr J. F. Masterson**  
Address: **Cassoday Kansas 66842**

Locate with "X" in section below:

Sketch map:



4 Well depth: **90** ft. Date of completion **7/19/75**  
Well diameter **10** in.

5  Cable tool  Rotary  Driven  Dug  
 Hollow rod  Jetted  Bored  Reverse rotary

6 Use:  Domestic  Public supply  Industry  
 Irrigation  Air conditioning  Commercial  
 Test well

7 Casing: Material **Steel** Height: above/below  
Threaded  Welded  Surface **12** in.  
Diam. **36** lbs./ft.  
**10** in. to **11** ft. depth Drive shoe?  Yes  No  
\_\_\_ in. to \_\_\_ ft. depth

2	Type and color of material	From	To
	<b>REWORK-</b>		
	<b>Pit</b>	<b>0</b>	<b>6</b>
	<b>15" Hole Lime</b>	<b>6</b>	<b>16</b>
	<b>Rework Enlarged F.6"--T.10"</b>	<b>16</b>	<b>90</b>
	<b>Untrue picture of formation</b>		
	<b>1.10" 36# Steel casing 12" above pit floor</b>		
	<b>2.15" Drilled hole</b>		
	<b>3.10" Drilled hole</b>		
	<b>4. Neat cement</b>		
	<b>5. Open uncased hole</b>		
	<b>This well was preinspected and postinspected by the Butler County Zoning Office under the Health Office.</b>		
	<b>This is a low yield well and can be bailed dry</b>		
	(use a second sheet if needed)		

8 Screen: **Not used**  
Manufacturer \_\_\_\_\_  
Type \_\_\_\_\_ Dia. \_\_\_\_\_  
Slot/gauze \_\_\_\_\_ Length \_\_\_\_\_  
Set between \_\_\_\_\_ ft. and \_\_\_\_\_ ft.  
Fittings:  
Gravel pack  Yes  No Size range of material \_\_\_\_\_

9 Static water level: **20** ft. below land surface Date **7/19/75**

10 Pumping level below land surfaces:  
\_\_\_ ft. after \_\_\_ hrs. pumping \_\_\_ g.p.m.  
\_\_\_ ft. after \_\_\_ hrs. pumping \_\_\_ g.p.m.  
Estimated maximum yield **1** g.p.m.

11 Water sample submitted:  
 Yes  No Date \_\_\_\_\_

12 Well head completion:  
 Pitless adapter **12** inches above grade

13 Well grouted?  Yes  No  
 Neat cement  Bentonite  \_\_\_\_\_  
Depth: From **0** ft. to **10** ft.

14 Nearest source of possible contamination:  
ft. **80** Direction **South** Type **Barn**  
Well disinfected upon completion?  Yes  No

15 Pump: **Myers Jet**  Not installed **Reinst.**  
Manufacturer's name **Myers**  
Model number **NA** HP **NA** Volts **NA**  
Length of drop pipe **70** ft. capacity **NA** g.m.p.  
Type:  
 Submersible  Turbine  
 Jet  Reciprocating  
 Centrifugal  Other

16 Remarks: elevation

Topography:

- Hill  
 Slope  
 Upland  
 Valley

17 Water well contractor's certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

**Abraham & Plummer 181**  
Business name \_\_\_\_\_ License No. \_\_\_\_\_  
Address **2740 W. 8 rd Eldorado, Ks**  
Signature **James S. Plummer** Date **7/23/75**  
Authorized representative