



USE TYPEWRITER OR BALL POINT PEN - PRESS FIRMLY, PRINT CLEARLY

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment - Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

SW 1/4 NE 1/4 NE 1/4

1. Location of well: County: Butler Fraction: SW 1/4 NE 1/4 NE 1/4 Section number: 21 Township number: T 23 S Range number: R 7 E/W

2. Distance and direction from nearest town or city: _____
Street address of well location if in city: _____
3. Owner of well: Arthur Stevens
R.R. or street: RR1
City, state, zip code: Cassoday, Kansas

4. Locate with "X" in section below: Sketch map: _____

6. Bore hole dia. 8 1/2 in. Completion date 11-10-96
Well depth 65 ft.

7. Cable tool Rotary Driven Dug
 Hollow rod Jetted Bored Reverse rotary

8. Use: Domestic Public supply Industry
 Irrigation Air conditioning Stock
 Lawn Oil field water Other

9. Casing: Material _____ Height: Above or below
Threaded _____ Welded _____ Surface _____ in.
RMP _____ PVC _____ Weight _____ lbs./ft.
Dia. _____ in. to _____ ft. depth Wall Thickness: inches or
Dia. _____ in. to _____ ft. depth gage No. _____

5. Type and color of material	From	To
Top Soil Black	0	4
Shale Brown	4	6
Shale Grey	6	12
Limestone Light Brown	12	63
Shale Grey	63	65
<p>This well was Filled with natural earth material From 65' to 25'. A cement plug was poured From 25' to 10' then was finished with natural earth material.</p>		

10. Screen: Manufacturer's name _____
Type _____ Dia. _____
Slot/gauze _____ Length _____
Set between _____ ft. and _____ ft.
_____ ft. and _____ ft.
Gravel pack? _____ Size range of material _____

11. Static water level: _____ mo./day/yr.
_____ ft. below land surface Date _____

12. Pumping level below land surfaces:
_____ ft. after _____ hrs. pumping _____ g.p.m.
_____ ft. after _____ hrs. pumping _____ g.p.m.
Estimated maximum yield 1 1/2 g.p.m.

13. Water sample submitted: _____ mo./day/yr.
_____ Yes _____ No Date _____

14. Well head completion:
 Pitless adapter _____ Inches above grade

15. Well grouted? _____
With: Neat cement Bentonite Concrete
Depth: From _____ ft. to _____ ft.

16. Nearest source of possible contamination:
ft. _____ Direction _____ Type _____
Well disinfected upon completion? Yes No

17. Pump: _____ Not installed
Manufacturer's name _____
Model number _____ HP _____ Volts _____
Length of drop pipe _____ ft. capacity _____ g.p.m.
Type:
 Submersible Turbine
 Jet Reciprocating
 Centrifugal Other

(Use a second sheet if needed)

18. Elevation: _____
19. Remarks: _____
Topography:
 Hill
 Slope
 Upland
 Valley

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Blascoe Drilling Co. 152
Business name License No.
Address Strong City, Ks
Signed Raymond P. Blascoe Date 2-1-97
Authorized representative

23 - 27
W
27
NE
1/4
1/4
1/4