


Sent to Leonard
6-17-77

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Butler	Fraction NE 1/4 SE 1/4 SW 1/4	Section number 23	Township number T 23 S R 7 EW	Range number																								
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: City of Cassoday Kansas R.R. or street: City, state, zip code: Cassoday, Kansas																										
4. Locate with "X" in section below:  Sketch map: Well #1			6. Bore hole dia 1 1/2 in. Completion date 5-10-77 Well depth 90 ft.																										
5. Type and color of material			7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary																										
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input checked="" type="checkbox"/> Other																										
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width:50%;"></th> <th style="width:10%;">From</th> <th style="width:10%;">To</th> </tr> </thead> <tbody> <tr> <td>Top Soil</td> <td>Black</td> <td>0 4</td> </tr> <tr> <td>Limestone</td> <td>yellow</td> <td>4 22</td> </tr> <tr> <td>Shale</td> <td>Grey</td> <td>22 26</td> </tr> <tr> <td>Limestone</td> <td>yellow</td> <td>26 35</td> </tr> <tr> <td>Shale</td> <td>Grey</td> <td>35 45</td> </tr> <tr> <td>Limestone</td> <td>yellow</td> <td>45 77</td> </tr> <tr> <td>Shale</td> <td>Grey</td> <td>77 90</td> </tr> </tbody> </table>				From	To	Top Soil	Black	0 4	Limestone	yellow	4 22	Shale	Grey	22 26	Limestone	yellow	26 35	Shale	Grey	35 45	Limestone	yellow	45 77	Shale	Grey	77 90	9. Casing: Material _____ Height: Above <input type="checkbox"/> below <input checked="" type="checkbox"/> Threaded _____ Welded <input checked="" type="checkbox"/> Surface 36 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 8 in. to 70 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 322		
				From	To																								
Top Soil	Black	0 4																											
Limestone	yellow	4 22																											
Shale	Grey	22 26																											
Limestone	yellow	26 35																											
Shale	Grey	35 45																											
Limestone	yellow	45 77																											
Shale	Grey	77 90																											
<p>These well is to be used to supply water for waste stabilization pond water</p> <p>Approval for the wells was given by Leonard J. Imhof, P.E., Chief Water Supply Section Bureau of water supply</p> <p>(Use a second sheet if needed)</p>			10. Screen: Manufacturer's name _____ Type _____ Dia. _____ Slot/gauze slot Length _____ Set between 20 ft. and 90 ft. _____ ft. and _____ ft. Gravel pack? NO Size range of material _____																										
			11. Static water level: _____ mo./day/yr. 27 ft. below land surface Date 5-10-77																										
18. Elevation:			12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 5 gpm g.p.m.																										
			13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____																										
19. Remarks: This well was finished according to the plans approved by the State. John A. Bledsoe			14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 24 inches above grade																										
			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 20 ft. to 2 ft.																										
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley			16. Nearest source of possible contamination: ft. 2,000 Direction West Type gas tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No																										
			17. Pump: _____ Not installed Manufacturer's name Jacuzzi Model number 154B18-S2 HP 1 Volts 230 Length of drop pipe 80 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																										
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Bledsoe Drilling Co 349 Business name _____ License No. _____ Address 1/4 mile Cottonwood Falls, KS Signed John A. Bledsoe Date 5-17-77 Authorized representative																													

23 - 20 23 NE SE SW
1/4 1/4 1/4