


Sent to Leonard
6-17-77

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Butler	Fraction NE 1/4 SW 1/4 SE 1/4	Section number 23	Township number T 23 S	Range number R 7 E
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: City of Cassoday Kansas R.R. or street: City, state, zip code: Cassoday, Kansas		
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 		
5. Type and color of material			6. Bore hole dia. 12 in. Completion date 5-10-77 Well depth 90 ft.		
			7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input checked="" type="checkbox"/> Other		
			9. Casing: Material _____ Height: Above or below <input checked="" type="checkbox"/> below Threaded _____ Welded <input checked="" type="checkbox"/> Surface 36 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. <input checked="" type="checkbox"/> in. to 90 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 322		
			10. Screens: Manufacturer's name _____ Type _____ Dia. _____ Slot/gauze slot Length _____ Set between 20 ft. and 90 ft. _____ ft. and _____ ft. Gravel pack? NO Size range of material _____		
			11. Static water level: _____ mo./day/yr. 12 ft. below land surface Date 5-10-77		
			12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 59 gpm g.p.m.		
			13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
			14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 24 Inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 20 ft. to 3 ft.		
			16. Nearest source of possible contamination: ft. 2800 Direction West Type gas tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: _____ Not installed Manufacturer's name Jacuzzi Model number LS4B18-S HP 1 Volts 230 Length of drop pipe 80 ft. capacity 20 g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine <input type="checkbox"/> Jet _____ Reciprocating <input type="checkbox"/> Centrifugal _____ Other		
18. Elevation:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Bledsoe Drilling Co. 349 Business name _____ License No. _____ Address 912 Maple Cottonwood Falls, KS Signed John A. Bledsoe Date 5-12-77 Authorized representative		
19. Remarks: This well was finished according to the plans approved by the State John A. Bledsoe					

		From	To
Top soil	Black	0	3
Limestone	yellow	3	62
Shale	Grey	62	65
Limestone	light yellow	65	67
Shale	Grey	67	82
Shale	Red-Brown	82	86
Shale	Grey	86	90

This well is to be used to supply water for waste stabilization pond water. Approval for the wells was given by

Leonard J. Imhof, PE Chief
Water Supply Section
Bureau of water supply

(Use a second sheet if needed)

23 - 20 23 NE SE