

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: Hornum	County C 1/4 SE 1/4 SE 1/4	Section number 1	Township number T 24 S R 1 E W
2. Distance and direction from nearest town or city: 3 1/4 miles Street address of well location if in city: off Main St. near intersection		3. Owner of well: Alfred Busenick R.R. or street: 5 City, state, zip code: Norton Kansas	
4. Locate with "X" in section below: <div style="text-align: center;">N NW NE SW SE S E 1 Mile</div>		Sketch map: 4 miles East of Ramada Inn, Newton, Ks. Then 3 1/4 miles so on west side	
5. Type and color of material		6. Bore hole dia. 3 1/2 in. Completion date Dec 12/10 Well depth 34 ft.	
		7. Cable tool ___ Rotary ___ Driven ___ Dug ___ Hollow rod ___ Jetted ___ Bored ___ Reverse rotary	
		8. Use: <input checked="" type="checkbox"/> Domestic ___ Public supply ___ Industry ___ Irrigation ___ Air conditioning ___ Stock ___ Lawn ___ Oil field water ___ Other	
		9. Casing: Material Plastic Height: Above or below Threaded ___ Welded <input checked="" type="checkbox"/> Surface 24 in. RMP <input checked="" type="checkbox"/> PVC ___ Weight 200 lbs./ft. Dia. ___ in. to ___ ft. depth Wall Thickness: inches or Dia. ___ in. to ___ ft. depth gage No. 5-42/10 10-	
		10. Screens: Manufacturer's name Sunflower plastic pipe inc Type RMP Dia. 5 and 10 Slot/gauze 3/32 Length 10 Set between ___ ft. and ___ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 7-1/2	
		11. Static water level: ___ mo./day/yr. 20 ft. below land surface Date Dec 12/10	
		12. Pumping level below land surfaces: 20 ft. after 25 hrs. pumping 18 g.p.m. ___ ft. after ___ hrs. pumping ___ g.p.m. Estimated maximum yield 20 g.p.m.	
		13. Water sample submitted: ___ mo./day/yr. Yes <input checked="" type="checkbox"/> No ___ Date ___	
		14. Well head completion: Pitless adapter 24 Inches above grade	
		15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement ___ Bentonite ___ Concrete Depth: From 3 ft. to 10 ft.	
		16. Nearest source of possible contamination: ft. 150' Direction No Type Coal Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ___ No ___	
		17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ___ Model number ___ HP ___ Volts ___ Length of drop pipe ___ ft. capacity ___ g.p.m. Type: ___ Submersible ___ Turbine ___ Jet ___ Reciprocating ___ Centrifugal ___ Other	
18. Elevation:		19. Remarks: Old WELL REWORKED	
Topography: ___ Hill ___ Slope <input checked="" type="checkbox"/> Upland ___ Valley		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Frank Buckle 221 Business name License No. Address B4 Signed Frank Buckle Date 1/6/11 Authorized representative	