

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County Allen	Fraction NE 1/4 NW NW 1/4 1/4	Section number 3	Township number T 24 S	Range number R 18 EW	
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: Freddie Suchy R.R. or street: R.R. 1, Iola, Kansas 66749 City, state, zip code: IOLA, KS 66749				
4. Locate with "X" in section below: Sketch map:			6. Bore hole dia. <u>6 1/2</u> in. Completion date <u>1/15/76</u> Well depth <u>202</u> ft.				
			7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary				
5. Type and color of material			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other				
Soil & joint clay & lime bolders			9. Casing: Material <u>plts</u> Height: Above or below Threaded <input type="checkbox"/> Welded <u>pl</u> Surface <u>18</u> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. <u>5</u> in. to <u>100</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. _____				
Blue lime			10. Screen: Manufacturer's name <u>VINYL PLEX SUPER PIPE</u> Type <u>PEVC 1120</u> Dia. <u>5</u> Slot/gauze <u>4</u> holes Length <u>25</u> ft. Set between <u>20</u> ft. and <u>40 to 60</u> ft. <u>5</u> ft. _____ ft. and <u>85 to 90</u> ft.				
White lime			11. Static water level: <u>40</u> ft. below land surface Date <u>1/14/76</u> mo./day/yr.				
Gray Shale			12. Pumping level below land surfaces: <u>dry</u> ft. after _____ hrs. pumping <u>5</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>2</u> g.p.m.				
Blue sandy Shale			13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____				
Gray Sand			14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u>18</u> Inches above grade				
Gray Shale			15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>18</u> ft. to <u>22</u> ft.				
White Lime			16. Nearest source of possible contamination: ft. <u>100</u> Direction <u>west</u> Type <u>Barn</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				
Gray Shale			17. Pump: _____ Not installed Manufacturer's name <u>Goulds</u> Model number <u>7</u> HP <u>2</u> Volts <u>230</u> Length of drop pipe <u>90</u> ft. capacity <u>5</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				
Trace of coal or slate			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>George H. Swank</u> License No. <u>107</u> Address <u>R.R. 1, Iola, Kansas</u> Signed <u>George H. Swank</u> Date <u>3/1/76</u> Authorized representative				
Gray Shale			<p>HOLE IS DRY AT THIS TIME AS VEINS IS BLOCKED OFF AT WELL WALL.</p> <p>(Use a second sheet if needed)</p>				
18. Elevation:		19. Remarks: This well had undiserable tasting water between 175&202. Plugged back to 115ft with crushed rock & dust & packed each 20ft with drilling tools to 155 ft. 1sack cement gruzzz rock to 100ft 1 sack cementwith rock on top to 95 ft. Water has slite mineral taste.		20. Water well contractor's certification:			
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley							

Forward the white, blue and pink copies to the Department of Health and Environment
CEMENT SLAB TO BE PUT ON IF WATER COMES IN SO AS TO MAKE A WELL.