

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

County Harvey		Fraction NE 1/4 NE 1/4 NE 1/4	Section number 13	Township number 24 S	Range number 2 E
1. Location of well: Harvey		2. Distance and direction from nearest town or city: 1 1/2 mi. N. of Whitewater, Kansas and 1/2 mi. W. and		3. Owner of well: Jay Sprecker R.R. or street: 407 East First City, state, zip code: Wichita, Kansas	
4. Locate with "X" in section below: 1 Mile		Sketch map: 300 yards South in field.		6. Bore hole dia. _____ in. Completion date Well depth 54 ft. 4-22-76	
5. Type and color of material		From	To	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Sandy topsoil		0	3	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Clay		3	16	9. Casing: Material STYRENE Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 54 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 200	
Shale		16	18	10. Screen: Manufacturer's name SUNFLOWER PLASTIC Type STYRENE Dia. 5" Slot gauge 1.06 Length 20 Set between 34 ft. and 54 ft. _____ ft. and _____ ft. Gravel pack? YES Size range of material 1/4 - 1/2"	
Clay		18	46	11. Static water level: _____ mo./day/yr. 35 ft. below land surface Date 4-22-76	
Shale		46	54	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input type="checkbox"/> No Date _____	
				14. Well head completion: 12 Capped <input type="checkbox"/> Pitless adapter _____ inches above grade	
				15. Well grouted? YES With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 40 1/2 to 14 ft.	
				16. Nearest source of possible contamination: None ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:		19. Remarks: Septic Tank not installed when well was drilled.			
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		20. Well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. HARP WELL & PUMP 236 Business name _____ License No. _____ Address WICHITA, KANSAS Signed M. Arnold Date 6-15-76 Authorized representative			