

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

X Location of well:		County Harvey	Fraction SE_{1/4} SE_{1/4} SW_{1/4}	Section number 34	Township number T 24 S R	Range number 2E_{1/4} W
X Distance and direction from nearest town or city: Street address of well location if in city: 125 th North on the No. side of the road, Furley, Kansas			3. Owner of well: David Dore R #1 Potwin, Kansas R.R. or street: City, state, zip code:			
4. Locate well "X" in section below: N Sketch map: side of the road, Furley, Kansas W E S 1 Mile 1 Mile			6. Bore hole dia. 11 in. Completion date 2-6-78 Well depth 60 ft. 7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary 8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other 9. Casing: Material styrene Height: Above or below 112 Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <input type="checkbox"/> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 60 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .200			
5. Type and color of material			From	To	10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5" Slot/gap .06 Length 40' Set between 20 ft. and 60 ft. Gravel pack? yes Size range of material 1/4-1 1/8"	
Topsoil			0	3	11. Static water level: 15 ft. below land surface Date 2-6-78	
Clay			3	10	12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.	
Fine Sand			10	17	13. Water sample submitted: yes mo./day/yr. 2-6-78	
Grey Shale			17	56	14. Well head completion: 12 capped Pitless adapter 12 Inches above grade	
Limestaone			56	60	15. Well grouted? yes 1-2 fine sand mix With: Neat cement <input checked="" type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete <input checked="" type="checkbox"/> Depth: From 40' ft. to 14 ft.	
					16. Nearest source of possible contamination: 100 ft. NW Direction Septic Tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)						
18. Elevation:	19. Remarks: Flat Ground		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name Wichita, Kansas License No. Address Signed My Arnold Date 3-15-78 Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						