

1 LOCATION OF WATER WELL
 County: Butler Fraction SW 1/4 SW 1/4 NW 1/4 Section Number 1 Township Number T 24 S Range Number R 4 EAN

Distance and direction from nearest town or city? 3 EAST & 3/4 North at Putwin Street address of well if located within city?

2 WATER WELL OWNER: HARLEY J. STUCKY
 RR#, St. Address, Box #: 2117 N MAIN
 City, State, ZIP Code: North NEWTON, KS 67117
 Board of Agriculture, Division of Water Resources
 Application Number:

3 DEPTH OF COMPLETED WELL: 105 ft. Bore Hole Diameter: 12 in. to 105 ft., and _____ in. to _____ ft.
 Well Water to be used as:
 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below)
 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Observation well STOCK
 Well's static water level: 8 ft. below land surface measured on _____ month 20 day 80 year
 Pump Test Data: Well water was _____ ft. after _____ hours pumping _____ gpm
 Est. Yield 50+ gpm: Well water was _____ ft. after _____ hours pumping _____ gpm


4 TYPE OF BLANK CASING USED:
 1 Steel 3 RMP (SR) 6 Asbestos-Cement 9 Other (specify below) Welded _____
 2 PVC 4 ABS 7 Fiberglass _____ Threaded _____
 Blank casing dia: 6" in. to 105 ft., Dia _____ in. to _____ ft., Dia _____ in. to _____ ft.
 Casing height above land surface: 18 in., weight 3.36 lbs./ft. Wall thickness or gauge No. 225

TYPE OF SCREEN OR PERFORATION MATERIAL:
 1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 11 Other (specify) _____
 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 12 None used (open hole)
 Screen or Perforation Openings Are:
 1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut factory 11 None (open hole)
 2 Louvered shutter 4 Key punched 6 Wire wrapped 020 Slot 9 Drilled holes
 7 Torch cut 10 Other (specify) _____
 Screen-Perforation Dia: 6" in. to 96 ft., Dia _____ in. to _____ ft., Dia _____ in. to _____ ft.
 Screen-Perforated Intervals: From 71 ft. to 31 ft., From _____ ft. to _____ ft., From _____ ft. to _____ ft.
 From 86 ft. to 96 ft., From _____ ft. to _____ ft., From _____ ft. to _____ ft.
 Gravel Pack Intervals: From 10 ft. to 105 ft., From _____ ft. to _____ ft., From _____ ft. to _____ ft.
 From _____ ft. to _____ ft., From _____ ft. to _____ ft., From _____ ft. to _____ ft.

5 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other _____
 Grouted Intervals: From 0 ft. to 10 ft., From _____ ft. to _____ ft., From _____ ft. to _____ ft.
 What is the nearest source of possible contamination:
 1 Septic tank 4 Cess pool 7 Sewage lagoon 11 Fertilizer storage 14 Abandoned water well
 2 Sewer lines 5 Seepage pit 8 Feed yard 12 Insecticide storage 15 Oil well/Gas well
 3 Lateral lines 6 Pit privy 9 Livestock pens 13 Watertight sewer lines 16 Other (specify below) _____
 Direction from well: South How many feet: 130' ? Water Well Disinfected? Yes _____ No
 Was a chemical/bacteriological sample submitted to Department? Yes _____ No No If yes, date sample was submitted _____ month _____ day _____ year Pump Installed? Yes _____ No
 If Yes: Pump Manufacturer's name: Pumpco Model No. 420594M .HP 3/4 Volts 230
 Depth of Pump Intake: 70 ft. Pumps Capacity rated at _____ gal./min.
 Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other _____

6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on _____ month _____ day _____ year and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 175
 This Water Well Record was completed on _____ month _____ day _____ year under the business name of PAUL'S INC by (signature) Paul Bunkert

7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:



FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG
0	5	LOAM TO RE BR CLAY			
5	10	RE BR clay to TAN limestone			
10	25	TAN LAYERED soft limestone			
25	28	FLINT ROCK			
28	40	SANDY COLORED LAYERED limestone			
40	42	FLINT ROCK			
42	50	RED-BROWN -SOFT SHALE			(HARD AT 55')
50	60	" " to blue GRAY soft SHALE			
65	70	Light GRAY to DARK GRAY SHALE			
70	76	DARK GRAY SHALE (FAULT at 74')			2 layers of white/clear mica
76	89	" " " (" " 89')			

ELEVATION: _____

Depth(s) Groundwater Encountered 89-105 ft. 2. " ft. 3. " ft. 4. " ft. (Use a second sheet if needed)

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.

OFFICE USE ONLY

T

24

R

4

EW

SEC

SW 1/4 SW 1/4 SW 1/4 NW 1/4