

5

LOCATION OF WATER WELL: Fraction SE 1/4 NE 1/4 NW 1/4 Section Number 9 Township Number T 25 S Range Number R 10 E
 County: Sedgwick Distance and direction from nearest town or city? 5 E, 1 So Sedgwick Street address of well if located within city?
 WATER WELL OWNER: DAN Alexander Board of Agriculture, Division of Water Resources
 RR#, St. Address, Box #: 825 E-117th No (Sedgwick) Application Number:
 City, State, ZIP Code:


DEPTH OF COMPLETED WELL: 50 ft. Bore Hole Diameter: 11 in. to ... ft., and ... in. to ... ft.
 Well Water to be used as:
 Domestic Feedlot Oil field water supply Air conditioning Injection well
 Irrigation Industrial Lawn and garden only Dewatering Other (Specify below)
 Observation well
 Well's static water level: 14 ft. below land surface measured on ... month 4 day 18 year
 Pump Test Data: Well water was ... ft. after ... hours pumping ... gpm
 Est. Yield 20-25 gpm: Well water was 17 ft. after 1/2 hours pumping 15 gpm

TYPE OF BLANK CASING USED:
 Steel RMP (SR) Asbestos-Cement Concrete tile Other (specify below)
 PVC ABS Fiberglass
 Casing Joints: Glued Clamped Welded Threaded
 Blank casing dia: 5 in. to ... ft., Dia: 30 in. to ... ft., Dia: ... in. to ... ft.
 Casing height above land surface: 120 in., weight: 150 lbs./ft. Wall thickness or gauge No: 0.200

TYPE OF SCREEN OR PERFORATION MATERIAL:
 Steel Stainless steel Fiberglass RMP (SR) Asbestos-cement Other (specify)
 Brass Galvanized steel Concrete tile ABS None used (open hole)
 Screen or Perforation Openings Are:
 Continuous slot Mill slot Gauzed wrapped Saw cut None (open hole)
 Louvered shutter Key punched Wire wrapped Drilled holes
 Torch cut Other (specify)
 Screen-Perforation Dia: 25 in. to ... ft., Dia: ... in. to ... ft., Dia: ... in. to ... ft.
 Screen-Perforated Intervals: From 30 ft. to 50 ft., From ... ft. to ... ft., From ... ft. to ... ft.
 Gravel Pack Intervals: From 13 ft. to 50 ft., From ... ft. to ... ft., From ... ft. to ... ft.

GROUT MATERIAL: Neat cement Cement grout Bentonite Other
 Grouted Intervals: From 3 ft. to 13 ft., From ... ft. to ... ft., From ... ft. to ... ft.
 What is the nearest source of possible contamination:
 Septic tank Cess pool Sewage lagoon Fuel storage Abandoned water well
 Sewer lines Seepage pit Feed yard Fertilizer storage Oil well/Gas well
 Lateral lines Pit privy Livestock pens Insecticide storage Other (specify below)
 Watertight sewer lines
 Direction from well: SE How many feet: 100 ? Water Well Disinfected? Yes No
 Was a chemical/bacteriological sample submitted to Department? Yes No
 If Yes, date sample was submitted ... month ... day ... year: Pump Installed? Yes No
 If Yes: Pump Manufacturer's name: FWW Model No. 1808C HP 3/4 Volt 220
 Depth of Pump Intake: 40ft ft. Pumps Capacity rated at: 15 gal./min.
 Type of pump: Submersible Turbine Jet Centrifugal Reciprocating Other

CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on 4 month 18 day 80 year
 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 8038
 This Water Well Record was completed on 29 month 80 day 80 year under the business name of Whitinger Drilling by (signature) Glenn Whinger

LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:	FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG
	0	3	TOP SOIL			
	3	16	RED CLAY			
	16	24	FINE SAND			
	24	27	RED CLAY			
	27	36	MED SAND			
	36	50	CHARCOAL SHALE			

ELEVATION:
 Depth(s) Groundwater Encountered 1. ... ft. 2. ... ft. 3. ... ft. 4. ... ft. (Use a second sheet if needed)
 INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.