

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County: SEDGWICK	Fraction: SE 1/4 SE 1/4 SE 1/4	Section number: 32	Township number: T 25 S R 1 E	Range number: 1
2. Distance and direction from nearest town or city:	3 E 3/4 S 1/4 W				
Street address of well location if in city:	VALLEY CENTER				
3. Owner of well:	PAUL MCCULLIEY				
R.R. or street:	RR 2				
City, state, zip code:	VALLEY CENTER KS				
4. Locate with "X" in section below:	Sketch map:		6. Bore hole dia. 10 in. Completion date 11-1-77 Well depth 65 ft.		
			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From	To	9. Casing: Material PITS Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 1.50 lbs./ft. Dia. 5 in. to 15 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. 200	
TOP SOIL		0	3	10. Screen: Manufacturer's name JVZ Type RMP Dia. 5 Slot/gauze .06 Length 30 ft Set between 35 ft. and 65 ft. ft. and <input type="checkbox"/> ft. Gravel pack? YES Size range of material 48	
CLAY SANDY BROWN		3	10	11. Static water level: <input type="checkbox"/> mo./day/yr. 10 ft. below land surface Date 11-1-77	
SAND FINE		10	20	12. Pumping level below land surfaces: 35 ft. after 1 hrs. pumping 10 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 10 g.p.m.	
UNCONSOLIDATED ROCK		20	35	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>	
SHALE GRAY		35	65	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 Inches above grade	
				15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.	
				16. Nearest source of possible contamination: 60 ft ft. SEPTIC Direction NE Type SEPTIC Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name pumpco Model number <input type="checkbox"/> HP 1/2 Volts 230 Length of drop pipe 55 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:		(Use a second sheet if needed)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. DR Well Service 211 Business name License No. Address 2810 3rd Avenue KS Signed [Signature] Date 1-8-78 Authorized representative	
19. Remarks: Mr McCulliey will pour 4'x4' slab around well he knows this is a regulation					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

T 25 S R 1 E Sec 32