

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County: Woodson	Fraction: NW 1/4 NW 1/4 NW 1/4	Section number: 22	Township number: T 25	Range number: R 14 E/W
2. Distance and direction from nearest town or city: 2N 3E AND		3. Owner of well: DARYL GRIFFITH				
Street address of well location if in city: 2N OF TORONTO KS		R.R. or street: RT #2				
		City, state, zip code: TORONTO KAN				
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 7 in. Completion date 1/14/88	
					Well depth 170 ft.	
					7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
					8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material PITS Height: Above or below Threaded <input type="checkbox"/> Welded OL Surface 12 in. RMP <input type="checkbox"/> PVC 1 Weight <input type="checkbox"/> lbs./ft. Dia. 6 in. to 170 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 280	
5. Type and color of material		From	To	10. Screen: Manufacturer's name JESS LOWELL		
DARK SOIL		0	2	Type PIC Dia. 6		
BOULDER LINE ROCKS		2	5	Slot/gauze 1/16 Length 20		
SANDSTONE		5	20	Set between 140 ft. and 170 ft. ft. and ft.		
GRAY SHALE		20	25	Gravel pack? <input type="checkbox"/> Size range of material		
RED BED		25	32	11. Static water level: <input type="checkbox"/> mo./day/yr. 20 ft. below land surface Date 1/14/88		
GRAY SHALE		32	34	12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 5 g.p.m.		
RED BED		34	44	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
GRAY SHALE		44	56	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
HARD ROCK LIME		56	71	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 15 ft.		
GRAY SHALE		71	120	16. Nearest source of possible contamination: OGC ft. 3000 Direction TOWARD Type HOUSE		
GRAY SAND		120	125	Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
GRAY SHALE		125	130	17. Pump: <input checked="" type="checkbox"/> Not installed		
GRAY SAND		130	135	Manufacturer's name		
WHITE SAND		135	145	Model number HP Valts		
GRAY SHALE		145	170	Length of drop pipe ft. capacity g.p.m.		
		170	172	Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)						
18. Elevation:		19. Remarks: MR GRIFFITH IS GOING TO FOR HIS OWN PUMP HE SAID HE WOULD DISINFECT THE PUMP COLUMN.			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. CUMMINGS WELL SERV 212 Business name License No. Address TORONTO KAN Signed John Cummings Date 1/14/88 Authorized representative	
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5