

1 LOCATION OF WATER WELL:		Fraction		Section Number		Township Number		Range Number																																																																			
County: Allen		NE 1/4 SE 1/4 NE 1/4		2		T 25 S		R 19 EW																																																																			
Distance and direction from nearest town or city street address of well if located within city?																																																																											
One Mile South & East of LaHarpe, Kansas																																																																											
2 WATER WELL OWNER: Allen County Landfill %Director of Public Works																																																																											
RR#, St. Address, Box # : 1 North Washington Board of Agriculture, Division of Water Resource																																																																											
City, State, ZIP Code : Iola, KS 66749 Application Number:																																																																											
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		4 DEPTH OF COMPLETED WELL: 101 ft. ELEVATION:																																																																									
		Depth(s) Groundwater Encountered 1. ft. 2. ft. 3. ft.																																																																									
		WELL'S STATIC WATER LEVEL 8.8 ft. below land surface measured on mo/day/yr																																																																									
		Pump test data: Well water was ft. after hours pumping gpm																																																																									
		Est. Yield gpm: Well water was ft. after hours pumping gpm																																																																									
		Bore Hole Diameter in. to ft., and in. to ft.																																																																									
WELL WATER TO BE USED AS:																																																																											
1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Monitoring well AMW-4D																																																																											
Was a chemical/bacteriological sample submitted to Department? Yes No X; If yes, mo/day/yr sample was submitted																																																																											
Water Well Disinfected? Yes No X																																																																											
5 TYPE OF BLANK CASING USED:																																																																											
1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile CASING JOINTS: Glued Clamped 2 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded 7 Fiberglass Threaded X																																																																											
Blank casing diameter 2 in. to 9.1 ft., Dia in. to ft., Dia in. to ft.																																																																											
Casing height above land surface 24 in., weight lbs./ft. Wall thickness or gauge No. Sch. 40																																																																											
TYPE OF SCREEN OR PERFORATION MATERIAL:																																																																											
1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 10 Asbestos-cement 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 11 Other (specify) 12 None used (open hole)																																																																											
SCREEN OR PERFORATION OPENINGS ARE:																																																																											
1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole) 2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes 7 Torch cut 10 Other (specify) Factory Slot																																																																											
SCREEN-PERFORATED INTERVALS: From 91 ft. to 101 ft., From ft. to ft.																																																																											
GRAVEL PACK INTERVALS: From 88 ft. to 102 ft., From ft. to ft.																																																																											
6 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other																																																																											
Grout Intervals: From 2 ft. to 85 ft., From 3 ft. to 88 ft., From ft. to ft.																																																																											
What is the nearest source of possible contamination:																																																																											
1 Septic tank 4 Lateral lines 7 Pit privy 10 Livestock pens 14 Abandoned water well 2 Sewer lines 5 Cess pool 8 Sewage lagoon 11 Fuel storage 15 Oil well/Gas well 3 Watertight sewer lines 6 Seepage pit 9 Feedyard 12 Fertilizer storage 16 Other (specify below) 13 Insecticide storage N/A																																																																											
Direction from well? How many feet?																																																																											
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>FROM</th> <th>TO</th> <th>LITHOLOGIC LOG</th> <th>FROM</th> <th>TO</th> <th>PLUGGING INTERVALS</th> </tr> </thead> <tbody> <tr> <td>0.</td> <td>2.2</td> <td>Topsoil & Rocks</td> <td>102</td> <td>140</td> <td>Bentonite Holeplug</td> </tr> <tr> <td>2.2</td> <td>8.5</td> <td>Iola Limestone</td> <td></td> <td></td> <td></td> </tr> <tr> <td>8.5</td> <td>10.5</td> <td>Lt Gr Limestone</td> <td></td> <td></td> <td></td> </tr> <tr> <td>10.5</td> <td>12.5</td> <td>Gr Limestone with Chirt</td> <td></td> <td></td> <td></td> </tr> <tr> <td>12.5</td> <td>36.7</td> <td>Chanute Shale</td> <td></td> <td></td> <td></td> </tr> <tr> <td>36.7</td> <td>44.5</td> <td>Gr Limestone</td> <td></td> <td></td> <td></td> </tr> <tr> <td>44.5</td> <td>87.6</td> <td>Chanute Shale</td> <td></td> <td></td> <td></td> </tr> <tr> <td>87.6</td> <td>100.5</td> <td>Gr Silty Limestone</td> <td></td> <td></td> <td></td> </tr> <tr> <td>100.5</td> <td>109.3</td> <td>Gr Shale</td> <td></td> <td></td> <td></td> </tr> <tr> <td>109.3</td> <td>140.0</td> <td>Tan Limestone Hard</td> <td></td> <td></td> <td></td> </tr> </tbody> </table>										FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS	0.	2.2	Topsoil & Rocks	102	140	Bentonite Holeplug	2.2	8.5	Iola Limestone				8.5	10.5	Lt Gr Limestone				10.5	12.5	Gr Limestone with Chirt				12.5	36.7	Chanute Shale				36.7	44.5	Gr Limestone				44.5	87.6	Chanute Shale				87.6	100.5	Gr Silty Limestone				100.5	109.3	Gr Shale				109.3	140.0	Tan Limestone Hard			
FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS																																																																						
0.	2.2	Topsoil & Rocks	102	140	Bentonite Holeplug																																																																						
2.2	8.5	Iola Limestone																																																																									
8.5	10.5	Lt Gr Limestone																																																																									
10.5	12.5	Gr Limestone with Chirt																																																																									
12.5	36.7	Chanute Shale																																																																									
36.7	44.5	Gr Limestone																																																																									
44.5	87.6	Chanute Shale																																																																									
87.6	100.5	Gr Silty Limestone																																																																									
100.5	109.3	Gr Shale																																																																									
109.3	140.0	Tan Limestone Hard																																																																									
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) 5/10/94 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 458 This Water Well Record was completed on (mo/day/yr) 5-31-94 under the business name of The Winnek Co., Inc. by (signature) Dale June Bowls																																																																											