



USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County BUTLER	Fraction NW 1/4 S E 1/4 SE 1/4	Section number 6	Township number T 25 S	Range number R 8 E
2. Distance and direction from nearest town or city: 5 1/2 mi. N of Street address of well location if in city: 1 1/2 E. ROSALIA		3. Owner of well: MUTTLE RANCH & TRUST R.R. or street: City, state, zip code: ROSALIA, KA				
4. Locate with "X" in section below:		Sketch map: 			6. Bore hole dia. 8 1/4 in. Completion date 9-12-78 Well depth 100 ft.	
		7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary				
5. Type and color of material		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other				
Top soil		9. Casing: Material P.V.C. Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 16 in. RMP <input type="checkbox"/> PVC GL Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 90 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 259				
Lime stone (White)		10. Screen: Manufacturer's name M.P.I. Type P.V.C. Dia. 5 Slot gauge 25/1000 Length 10 Set between 90 ft. and 100 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft.				
SHALE (GRAY)		Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/8				
Lime stone (White)		11. Static water level: <input type="checkbox"/> mo./day/yr. 30 ft. below land surface Date 9-12-78				
SHALE (GRAY)		12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 8 g.p.m.				
		13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date 9-12-78				
		14. Well head completion: CAP. <input type="checkbox"/> Pitless adapter 16 inches above grade				
		15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.				
		16. Nearest source of possible contamination: ft. 150 Direction NE. W. Type S. tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				
		17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				
18. Elevation:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. P.R.W. Const 353 Business name BOY 744 License No. Address Auth P.R.W. Date 9-12-78 Signed Auth P.R.W. Authorized representative				
19. Remarks: Owner will see that Old well is Plug. as soon possible. x Umetha Maddy						