

USE TYPEWRITER OR BALL,
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

NE SW NE NW

1. Location of well:		County Sedgwick	Fraction 1/4 NW 1/4 SW 1/4	Section number 21	Township number T 26 S	Range number R 1 E
2. Distance and direction from nearest town or city: 2 mi No. Wichita			3. Owner of well: Joe Lee			
Street address of well location if in city: 5228 Primrose			City, state, zip code: Wichita KS			
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: Lot 6		6. Bore hole dia. 8 in. Completion date 12/14/76 Well depth 40 ft.		
		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input checked="" type="checkbox"/> Other		
		9. Casing: Material <input type="checkbox"/> Threaded <input type="checkbox"/> Welded <input type="checkbox"/> RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Height: Above or below Surface 12 in. Weight 100 lbs./ft. Dia. 5 in. to 40 ft. depth Wall Thickness: inches or Dia. 1/4 in. to 1/4 ft. depth gauge No. 1/4		10. Screen: Manufacturer's name Sunflower Type 100 Dia. 5 Slot/gauze Slot Length 40 Set between 35 ft. and 40 ft. Gravel pack? No Size range of material		
5. Type and color of material		From	To	11. Static water level: 13 ft. below land surface Date 12/14/76 mo./day/yr.		
Gray Sand		0'	13'	12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 5 g.p.m.		
Yellow Sand		13'	34'	13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date		
White Sand		34'	40'	14. Well head completion: <input type="checkbox"/> Pitless adapter ____ inches above grade		
				15. Well grouted? Owner With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From ____ ft. to ____ ft.		
				16. Nearest source of possible contamination: ft. 300 Direction NW Type Sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number ____ HP ____ Volts Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Jet Drilling 313 Business name (License No.) Address 257 N. Sabin Signed Kim H. Hancock Date 12/14/76 Authorized representative		
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5