

USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Sedgwick	Fraction 1/4 NW 1/4 NW 1/4	Section number 3	Township number T 26 S	Range number R 1E E/W
2. Distance and direction from nearest town or city: 7722 North Hydraulic			3. Owner of well: Larry Mukes			
Street address of well location if in city: Wichita, Kansas			R.R. or street: 3828 Lavon			
			City, state, zip code: Wichita, Kansas			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>11</u> in. Completion date <u>10-21-77</u>		
				Well depth <u>75</u> ft.		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <u>styrene</u> Height: Above or below <u>12</u> in. Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>81</u> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <u>75</u> lbs./ft. Dia. <u>5</u> in. to <u>75</u> ft. depth Wall Thickness: inches or Dia. <u>5</u> in. to <u>75</u> ft. depth Gauge No. <u>200</u>		
5. Type and color of material		From	To	10. Screen: Manufacturer's name <u>Sunflower Plastic</u>		
				Type <u>styrene</u> Dia. <u>5"</u>		
Topsoil		0	3	Slot/gauge <u>.06</u> Length <u>40'</u>		
Clay		3	31	Set between <u>35</u> ft. and <u>75</u> ft. ft. and <u>75</u> ft.		
Fine Sand		31	38	Gravel pack? <input checked="" type="checkbox"/> Yes Range of material <u>1/2-1 1/8"</u>		
Grey Shale		38	75	11. Static water level: <u>20</u> ft. below land surface Date <u>10-21-77</u>		
				12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.		
				13. Water sample submitted: ____ mo./day/yr. Yes <input type="checkbox"/> No <input type="checkbox"/> Date ____		
				14. Well head completion: <u>12</u> capped Pitless adapter ____ inches above grade		
				15. Well grouted? <u>yes</u> <u>1-2</u> fine sand With: <u>Neat cement</u> <u>Bentonite</u> <input checked="" type="checkbox"/> Concrete Depth: From <u>40'</u> ft. to <u>14</u> ft.		
				16. Nearest source of possible contamination: <u>Lagoon</u> ft. <u>150</u> Direction <u>NE</u> Type <u>X</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)						
18. Elevation:	19. Remarks:			20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	Flat Ground			This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name <u>Wichita, Kansas 67209</u> License No. ____ Address <u>M. Arnold</u> Signed <u>M. Arnold</u> Date <u>11-23-77</u> Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5