


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Sedgwick	Fraction 1/4 SE 1/4 SW 1/4	Section number 7	Township number T 26 S	Range number R 1E E/W
2. Distance and direction from nearest town or city: Street address of well location if in city: 6200 Bella Road Valley Center, Kansas			3. Owner of well: Daryl Catron Construction R.R. or street: 5401 Delaware City, state, zip code: Wichita, Kansas 67204		
4. Locate with "X" in section below: <div style="text-align: center;">  </div> Sketch map:			6. Bore hole dia. 11 in. Completion date 9-8-78 Well depth 45 ft.		
5. Type and color of material			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material Styrene Height: Above or below 12 in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 12 lbs./ft. Dia. 5 in. to 45 ft. depth Wall thickness: inches or Dia. 5 in. to 45 ft. depth gage No. 200		
			10. Screen: Manufacturer's name Sunflower plastic Type styrene Dia. 5" Slot/gauge .06 Length 12' Set between 33 ft. and 45 ft. Gravel pack? yes Size range of material 1/4-1/8"		
Topsoil			11. Static water level: 15 ft. below land surface Date 9-8-78		
Clay			12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.		
Fine sand			13. Water sample submitted: ____ mo./day/yr. ____ Yes ____ No Date ____		
Medium sand			14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade		
			15. Well grouted? yes 1-2 fine sand mix With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 40" ft. to 14 ft.		
			16. Nearest source of possible contamination: ft. ____ Direction ____ Type None Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ____ No		
			17. Pump: ____ Not installed Manufacturer's name Jacuzzi Model number 7S4C HP 3/4 Volts 230 Length of drop pipe 30 ft. capacity 20 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)					
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: Flat ground Septic system not installed at this time No apparent source for contamination		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name Address Wichita, Kansas 67209 Signed M. Ornel Date 10-2-78 Authorized representative		

26-10-7
R
Sec
1/4
1/4
1/4
SE SW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5