

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Sedgwick	Fraction SE SW NE SW 1/4 SE 1/4 SW 1/4	Section number 17	Township number T 26 S R	Range number 1 E
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: R.R. or street: City, state, zip code:			
5552 North Shelton Wichita, Kansas			Mr. Harold Roberts 5552 North Shelton Wichita, Kansas			
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: 		6. Bore hole dia. 11 in. Completion date 11-19-76 Well depth 45 ft.	
5. Type and color of material			From	To	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Sandy Topsoil			0	1	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Clay			1	12	9. Casing: Material styrene Height: Above or below 11 Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 45 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. 200	
Medium Sand			12	43	10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5 in. Slot/gauge .06 Length 10 ft. Set between 35 ft. and 45 ft. Gravel pack? yes Size range of material 1-1/8	
Shale			43	45	11. Static water level: 15 ft. below land surface Date 11-19-76 mo./day/yr.	
					12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.	
					13. Water sample submitted: mo./day/yr. Yes No Date	
					14. Well head completion: 12 capped Pitless adapter inches above grade	
					15. Well grouted? yes With: Neat cement Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 40 ft. to 14 ft.	
					16. Nearest source of possible contamination: Septic Tank ft. 60 Direction SE Type Tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes No	
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: Submersible Turbine Jet Reciprocating Centrifugal Other	
(Use a second sheet if needed)						
18. Elevation: Topography: Hill Slope Upland Valley	19. Remarks: Flat Ground		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name License No. Address Wichita, Kansas Signed M. Arnold Date 12-18-76 Authorized representative			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5