


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County SEDGWICK	Fraction NW 1/4 NW 1/4	Section number 18	Township number T 26 S R 1E E/W	Range number
2. Distance and direction from nearest town or city: 2215 W. 60th N. Wichita, Kansas Street address of well location if in city:				3. Owner of well: James Catron Construction R.R. or street: 3246 N. Clarence City, state, zip code: Wichita, Kansas		
4. Locate with "X" in section below: 			Sketch map:			
5. Type and color of material			From	To	6. Bore hole dia. 11 in. Completion date _____ Well depth 43 ft. 8-1-78	
Topsoil			0	3	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Clay			3	10	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Fine Sand			10	30	9. Casing: Material Styrene Height: Above or below _____ Threaded _____ Welded gl Surface 12 in. RMP <input checked="" type="checkbox"/> PVC _____ Weight _____ lbs./ft. Dia. 5 in. to 43 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 200	
Medium Sand			30	43	10. Screen: Manufacturer's name _____ Sunflower Plastic Type styrene Dia. 5" Slot/pipe .06 Length 10' Set between 33 ft. and 43 ft. _____ ft. and _____ ft. Gravel pack? yes Size range of material 1/4-1/8"	
					11. Static water level: _____ mo./day/yr. 15 ft. below land surface Date 8-1-78	
					12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
					13. Water sample submitted: _____ mo./day/yr. Yes _____ No _____ Date _____	
					14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade	
					15. Well grouted? yes 1-2 Fine Sand Mix With: _____ Neat cement _____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 40" ft. to 14 ft.	
					16. Nearest source of possible contamination: ft. _____ Direction _____ Type NONE Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No _____	
					17. Pump: _____ Not installed Manufacturer's name Jacuzzi Model number 7S4C HP 3/4 Volts 230 Length of drop pipe 27 ft. capacity 20 g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other	
(Use a second sheet if needed)						
18. Elevation:	19. Remarks: Flat Ground Septic system not installed at this time. No apparent source for contamination.		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name License No. Address Wichita, Kansas 67209 Signed M. Arnold Date 8-24-78 Authorized representative			
Topography: ____ Hill ____ Slope ____ Upland ____ Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5