


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Sedgwick	Fraction NW 1/4 NW 1/4 NW 1/4	Section number 18	Township number T 26 S R 1E	Range number E/W
2. Distance and direction from nearest town or city: 2300 West, 60th St. N Street address of well location if in city: Rio Vista Estates.			3. Owner of well: Richard Weir R.R. or street: 2801 Woodland City, state, zip code: Wichita, Kansas			
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. 11 in. Completion date 3-28-77 Well depth 40 ft.			
5. Type and color of material			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
			9. Casing: Material Styrene Height: Above or below 12 in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 12 lbs./ft. Dia. 5 in. to 40 ft. depth Wall Thickness: inches or Dia. 5 in. to 40 ft. depth gage No. 200			
			10. Screen: Manufacturer's name Sunflower Plastic Type Styrene Dia. 5 " Slot/gauze .06 Length 10' Set between 30 ft. and 40 ft. Gravel pack? yes Size range of material 1-1/8"			
			From	To	11. Static water level: 15 ft. below land surface Date 3-28-77 mo./day/yr.	
Topsoil			0	3	12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.	
Fine Sand			3	20	13. Water sample submitted: ____ Yes ____ No Date ____ mo./day/yr.	
Medium Sand			20	40	14. Well head completion: well seal ____ Pitless adapter 12 inches above grade	
					15. Well grouted? yes With: ____ Neat cement ____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 6 ft. to 16 ft.	
					16. Nearest source of possible contamination: NONE ft. ____ Direction ____ Type ____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ____ No	
					17. Pump: Not installed Manufacturer's name Sta-Rite Model number 20P4D02 HP 3/4 HP 230 Length of drop pipe 30 ft. capacity 20 g.p.m. Type: <input checked="" type="checkbox"/> Submersible ____ Turbine ____ Jet ____ Reciprocating ____ Centrifugal ____ Other	
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: ____ Hill ____ Slope <input checked="" type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley		Well To be in the basement. Septic System not installed when the Well was drilled. No apparent source for contamination.		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name Wichita, Kansas License No. ____ Address Wichita, Kansas Signed Marnold Date 5-25-77 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5