


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County SEDGWICK	Fraction NW 1/4 NW 1/4	Section number 18	Township number T 26 S R 1E E/W	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city: 2327 Ventoso Road Valley Center, Ks.				3. Owner of well: R.R. or street: Robert Muzzy Construction 734 Butler Valley Center, Ks. City, state, zip code:		
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 		6. Bore hole dia. 11 in. Completion date 4-1-78 Well depth 45 ft.		
5. Type and color of material		From		To		7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
						8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
						9. Casing: Material styrene Height: Above or below 11 Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 120 lbs./ft. Dia. 5 in. to 45 ft. depth Wall Thickness: inches or Dia. 5 in. to 45 ft. depth gage No. 200
						10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5" Slot/size .06 Length 10' Set between 35 ft. and 45 ft. Gravel pack? yes Size range of material 1/4-1/8"
						11. Static water level: 15 ft. below land surface Date 4-1-78 mo./day/yr.
(Use a second sheet if needed)						12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.
						13. Water sample submitted: ____ mo./day/yr. Yes ____ No ____ Date ____
						14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade
						15. Well grouted? yes 1-2 fine sand mix With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From ____ ft. to ____ ft.
						16. Nearest source of possible contamination: NONE ft. ____ Direction ____ Type ____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ____ No ____
18. Elevation:		19. Remarks: Flat Ground Septic system not installed at this time. No apparent source for contamination		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name Address: Wichita, Kansas License No. 67209 Signed: M. Arnold Date 7-10-78 Authorized representative		
						17. Pump: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
						Manufacturer's name Sta-Rite Model number 20P4D02 HP 3/4 Volts 230 Length of drop pipe 30 ft. capacity 20 g.p.m.
						Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5