WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors)

					Topeka, Kansas 66620	
	County	Fraction	Section	on number	Township number Range number	
1. Location of well:	Sedgwick	NW 1/4 NW 1/4 NW	1/4	18	T 26 S R 1E E/W	v }
2. Distance and dire	action from nearest town or city:		3. Owner of w	ell:	John Bitting Constr.	
Street address of well location if in city: 2419 Ventoso Road R.R. or					1255 High Wichita, Kansas 67203	
Valley Center, Kansas City, state, zip cod				p code:		
4. Locate with "X"		Sketch map:			6. Bore hole dia. 11 in. Completion date	7
					Well depth 45 ft. 12-5-77	-1
x					7 Cable tool X Rotary Driven Dug	
NW	NE				Hollow rod Jetted Bored Reverse rota	гу
W					8. Use: X Domestic Public supply Industry Irrigation Air conditioning Stock Lawn Oil field water Other	
<u> </u>	1				Threaded Welded g1 Surface 12	۱.
S					RMP_X PVClbs./f	t.
1 Mile → I				T -	Dia. 5 in. to 45 ft. depth Wall Thickness: inches or Dia. in. to ft. depth gage No. 200	
5. Type and color of	material		From	То	10. Screen: Manufacturer's name	=
					Sunflower Plastic	-
		·		+	Type styrene Dia. 5"	-
Topsoil			0	2	Slot/ga/zk	-
Sandy Soil			2	15	Gravel pack? Yes Size range of material 4-1/8	1
Fine Sand			15	25	11 a Static water level: 1 2 mos / daw/yr	
rine Sand			13	25	ft. below land surface Date 12-3-77	1
Medium to Coarse Sand			25	30	12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m	
Coarse Sand with Fine Gravel			30	45	ft. after hrs. pumping g.p.m	
			- 130	175	Estimated maximum yieldg.p.m	
					13. Water sample submitted: mo./day/yr	\cdot
					Yes No Date	
				†	14. Well head completion: 12 Inches above grade	
				+-	15. Well grouted? yes 1-2 fine sand m	
					With: Neat cement Bentonite X Concrete Depth: From 40^{ii} ft. to 14 ft.	_ [
						⊣ ⊀
					16. Negrest source of possible contamination: Septic ft. 65 Direction West Type Tank	
					Well disinfected upon completion? X Yes N	ا ا
					17. Pump: Not installed	٦ _≂ ڔ
				-	Manufacturer's name Sta-Rite Model number 20P4D02 HP _ 3/4 Volts _ 23	4
					Model number 20F4D02 HP 374 Volts 23 Length of drop pipe 35 ft. capacity 20 g.p.m.	-
				1	Type:	
					X Submersible Turbine	
	(Use a second sh	neet if needed)			Jet Reciprocating Other	×
18. Elevation:	19. Remarks:				20. Water well contractor's certification:	٩
Flat Ground					This well was drilled under my jurisdiction and this report	'
					is true to the best of my knowledge and belief.	-7
Topography:					Harp Well & Pump 236	44 -
Hill Slope					Business name Address Wichita, Kansas	<u>. ~</u> j
Upland					Signed M. Ornoldate	
Valley					Authorized representative 12-31-7	Z ≤ d

Forward the white, blue and pink copies to the Deportment of Health and Environment

Form WWC-5