WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment–Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County Sedgwick	Fraction $5E$ SW NE NW ~~NW~~ 1/4 ~~NE~~ 1/4 ~~NW~~ 1/4	Section number 18	Township number T 26 S	Range number R 1E E/W

2. Distance and direction from nearest town or city: 1933 West 60th North	3. Owner of well: Daryl Catron Construction
Street address of well location if in city: Wichita, Kansas	R.R. or street: 5401 Delaware
	City, state, zip code: Wichita, Kansas 67204

4. Locate with "X" in section below: Sketch map:

N

W   1 Mile   E

| NW | NE |
| SW | SE |

S

|← 1 Mile →|

6. Bore hole dia. __11__ in. Completion date _____
Well depth __45__ ft. __10-24-78__

7. __ Cable tool __X__ Rotary __ Driven __ Dug
__ Hollow rod __ Jetted __ Bored __ Reverse rotary

8. Use: __X__ Domestic __ Public supply __ Industry
__ Irrigation __ Air conditioning __ Stock
__ Lawn __ Oil field water __ Other

9. Casing: Material __styrene__ Height: Above or ~~below~~
Threaded _____ Welded __g1__ Surface __12__ in.
RMP __X__ PVC _____ Weight _____ lbs./ft.
Dia. __5__ in. to __45__ ft. depth Wall Thickness: inches or
Dia. __ in. to __ ft. depth gage No. __.200__

5. Type and color of material	From	To
Topsoil	0	3
Clay	3	10
Fine sand	10	28
Clay	28	31
Medium sand	31	45
(Use a second sheet if needed)		

10. Screen: Manufacturer's name __Sunflower plastic__
Type __styrene__ Dia. __5"__
Slot/~~gauge~~ __.06__ Length __10'__
Set between __35__ ft. and __45__ ft.
_____ ft. and _____ ft.
Gravel pack? __yes__ Size range of material __¼-1/8"__

11. Static water level: mo./day/yr.
__15__ ft. below land surface Date __10-24-78__

12. Pumping level below land surfaces:
_____ ft. after _____ hrs. pumping _____ g.p.m.
_____ ft. after _____ hrs. pumping _____ g.p.m.
Estimated maximum yield _____ g.p.m.

13. Water sample submitted: mo./day/yr.
____ Yes ____ No Date _____

14. Well head completion:
__X__ Pitless adapter __12__ Inches above grade

15. Well grouted? __yes 1-2fine sand mix__
With: ____ Neat cement ____ Bentonite __X__ Concrete
Depth: From __40"__ ft. to __14__ ft.

16. Nearest source of possible contamination:
ft. _____ Direction _____ Type __None__
Well disinfected upon completion? __X__ Yes ____ No

17. Pump: ____ Not installed
Manufacturer's name __Jacuzzi__
Model number __7S4C__ HP __3/4__ Volts __230__
Length of drop pipe __28__ ft. capacity __18__ g.p.m.
Type:
__X__ Submersible   ____ Turbine
____ Jet   ____ Reciprocating
____ Centrifugal   ____ Other

18. Elevation:	19. Remarks:	20. Water well contractor's certification:
	Flat Ground	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Topography:	Septic system not installed at this time	Harp Well & Pump 236
____ Hill	No apparent source for contamination	Business name
____ Slope		Address Wichita, Kansas 67209 License No.
____ Upland		Signed _M. Arnold_ Date 12-4-78
____ Valley		(Authorized representative)

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

M1-1023