


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

NW SE NW NE

1. Location of well:	County SEDGWICK	Fraction 3/4 NW 1/4	Section number 19	Township number T 26 S R 1 E	Range number 1
2. Distance and direction from nearest town or city:	Street address of well location if in city: 1629 W 52 N WICHITA, KANS.		3. Owner of well: DAVE BLOIR R.R. or street: 1629 W 52 N. City, state, zip code: WICHITA, KANS 67204		
4. Locate with "X" in section below:	Sketch map: 		BORED 9" HOLE TO 10' THEN 6" TO 13' INSTALLED CASING + USED SAND BUCKET TO COMPLETE		
5. Type and color of material	From	To	6. Bore hole dia. 7 in. Completion date 3/27/80 Well depth 31 ft. GRADE		
TOP SOIL	0	2	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input checked="" type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
SUB SOIL SANDY TAN	2	5	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
SAND FINE TAN	5	9	9. Casing: Material RMP Height: Above or below Threading Welded Surface 12 in. RMP X PVC <input type="checkbox"/> Weight 155 lbs./ft. Dia. 5 in. to 32 ft. depth Wall Thickness: inches or Dia. 5 in. to 32 ft. depth gage No. 200		
CLAY GRAY	9	10	10. Screen: Manufacturer's name CER-MAC Type RMP Dia. 5" Slot/gauze .031 Length 731 Set between 24 ft. and 31 ft. Gravel pack? NO Size range of material		
SAND COARSE GRAY	10	12	11. Static water level: 14 ft. below land surface Date 4/27/80		
SAND TAN COARSE	12	20	12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping NA g.p.m. ____ ft. after ____ hrs. pumping 60 g.p.m. Estimated maximum yield 60 g.p.m.		
SAND BROWN COARSE	20	22	13. Water sample submitted: X Yes <input type="checkbox"/> No Date		
SAND TAN COARSE	22	31	14. Well head completion: ____ Pitless adapter 12 Inches above grade		
			15. Well grouted? YES With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: ft. 68 Direction NW Type LATERAL Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
			17. Pump: Not installed Manufacturer's name RTLO Model number CR5675 HP .75 Volts 115 Length of drop pipe 22 ft. capacity 20 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input checked="" type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation: 1300	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief BEARDEN PUMP & WELL Business name 3142 MENTOR License No. WICHITA Address Chs W Beards Date 4/9/80 Signed Chs W Beards Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5