

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County <u>Sedgewick</u> Fraction <u>NE 1/4 SW 1/4</u> Section number <u>18</u> Township number <u>T 26 S</u> Range number <u>R 10 E</u>	
2. Distance and direction from nearest town or city: Street address of well location <u>SS65 Athenian</u>	
3. Owner of well: <u>LEEWOOD Homes</u> R.R. or street: <u>5228 Purmose</u> City, state, zip code: <u>Wichita KS 67204</u>	
4. Locate with "X" in section below: Sketch map: <p>Well in basement → House</p>	
6. Bore hole dia. <u>4 1/2</u> in. Completion date <u>1-9-80</u> Well depth <u>44</u> ft.	
7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Off-farm water <input type="checkbox"/> Other	
9. Casing <u>Stainless</u> Height <u>92</u> Above or below Threaded <input checked="" type="checkbox"/> Welded <input type="checkbox"/> Surface <input type="checkbox"/> in. RMP <u>5</u> PVC <input type="checkbox"/> Weight <u>1.30</u> lbs./ft. Dia. <u>5</u> in. to <u>4 1/2</u> ft. depth Wall Thickness: inches or Dia. <u>5</u> in. to <u>4 1/2</u> ft. depth gage No. <u>200</u>	
10. Screen: Manufacturer's name <u>Cumax</u> Type <u>200</u> Dia. <u>5 1/2</u> Slot/gauze <u>1/16</u> Length <u>10 ft</u> Set between <u>34</u> ft. and <u>44</u> ft. Gravel pack <u>4/10</u> size range of material <u>3/8</u>	
11. Static water level: <u>17</u> ft. below land surface Date <u>1-9-80</u>	
12. Pumping level below land surfaces: <u>14</u> ft. after <u>10</u> hrs. pumping <u>20</u> g.p.m. <u>16</u> ft. after <u>10</u> hrs. pumping <u>20</u> g.p.m. Estimated maximum yield <u>75</u> g.p.m.	
13. Water sample submitted: <u>1-9-80</u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
14. Well head completion: <u>12</u> inches above grade <input type="checkbox"/> Pitless adapter	
15. Well grouted? <u>yes</u> With: <u>Neat cement</u> <input checked="" type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>6</u> ft. to <u>16</u> ft.	
16. Nearest source of possible contamination: <u>none</u> ft. <u>none</u> Direction <u>none</u> Type <u>none</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u>Whisper</u> Model number <u>36</u> HP <u>1/4</u> Volts <u>115</u> Length of drop pipe <u>10</u> ft. capacity <u>10</u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation: <u>18</u>	
19. Remarks: <u>New Construction</u>	
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Whisper Pumping</u> Business name License No. <u>36</u> Address <u>Cherokee St</u> Signed <u>Whisper Pumping</u> Authorized representative Date <u>1-9-80</u>	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5