


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Sedgwick	Fraction NW 1/4 NW 1/4 SW 1/4	Section number 18	Township number T 26 S	Range number R 1E E/W	
2. Distance and direction from nearest town or city: Street address of well location if in city: 5710 North Sedgwick Wichita, Kansas			3. Owner of well: Joe Lee, Leewood Homes R.R. or street: 5228 Primrose City, state, zip code: Wichita, Kansas				
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 		6. Bore hole dia. 11 in. Completion date 3-21-78 Well depth 40 ft.		
5. Type and color of material			From		To		7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
							8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
							9. Casing: Material styrene Above or below 11 ft. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 40 ft. depth Wall Thickness: <input type="checkbox"/> inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .200
							10. Screen: Manufacturer's name Sunflower Type styrene Dia. 5" Slot/gauge .06 Length 10' Set between 30 ft. and 40 ft. Gravel pack? <input checked="" type="checkbox"/> yes Range of material 1-1/8"
							11. Static water level: 15 ft. below land surface Date 3-21-78 mo./day/yr.
(Use a second sheet if needed)							12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.
							13. Water sample submitted: ____ mo./day/yr. Yes ____ No ____ Date ____
							14. Well head completion: 12 capped ____ Pitless adapter ____ Inches above grade
							15. Well grouted? yes 1-2 fine sand mix With: ____ Neat cement ____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 6 ft. to 16 ft.
							16. Nearest source of possible contamination: NONE ft. ____ Direction ____ Type ____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ____ No ____
							17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: ____ Submersible ____ Turbine ____ Jet ____ Reciprocating ____ Centrifugal ____ Other
							20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name Wichita, Kansas License No. ____ Address ____ Signed M. Arnold Date 3-22-78 Authorized representative
							18. Elevation:
							19. Remarks: Flat Ground Septic system not installed at this time. No apparent source for contamination.
							Topography: ____ Hill ____ Slope ____ Upland ____ Valley

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

Well will be in the basement.