


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County SEDGWICK	Section SE 1/4 NW 1/4 NW 1/4	Section number 18	Township number T 26 S	Range number R 1E
2. Distance and direction from nearest town or city: 6009 North St. Clair Street address of well location if in city: Wichita, Kansas			3. Owner of well: Mrs. Raymond R.R. or street: 6009 North St. Clair City, state, zip code: Wichita, Kansas		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: 		
5. Type and color of material			From	To	6. Bore hole dia. 11 in. Completion date 1-25-79 Well depth 45 ft.
Topsoil			0	2	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Sandy Clay			2	8	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Medium Sand			8	20	9. Casing: Material styrene Height: Above or below 11 ft. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 45 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 200
Coarse Sand			20	30	10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5" Slot/gauge 1/4" 06 Length 15' Set between 30 ft. and 45 ft. ft. and 1-1/8" ft. Gravel pack? yes Size range of material 1-1/8"
					11. Static water level: <input type="checkbox"/> mo./day/yr. 13 ft. below land surface Date 1-25-79
					12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.
					<input checked="" type="checkbox"/> Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date
					14. Well head completion: 12 capped <input type="checkbox"/> Pitless adapter 12 inches above grade
					15. Well grouted? yes 1-2 fine sand mix With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 3 ft. to 14 ft.
					16. Nearest source of possible contamination: ft. 60 Direction S.E. Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No tank
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	Flat ground		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name License No. Address Wichita, Kansas 67209 Signed M. Arnold Date 3-1-79 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5