


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County SEDOGWICK	Fraction S 1/4 NE 1/4	Section number 19	Township number T 26	Range number S 1 R 1 E/W
2. Distance and direction from nearest town or city:		3. Owner of well: BILL SANDERSON				
Street address of well location if in city: 5250 N. ATHENIAN WICHITA KANS		City, state, zip code: WICHITA KANS 67204				
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 9 in. Completion date 7/28/78 Well depth 30 ft. FROM GRADE	
		BORED 9 INCH HOLE TO 14 FT. - H2O AT THIS DEPTH - INSTALLED CASING & COMPLETED WELL WITH SAND BUCKET			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
TOP SOIL BLACK		0	3	9. Casing: Material RMP Height: Above or below Threading 3/4 Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 155 lbs./ft. Dia. 5 in. to 30 ft. depth Wall Thickness: inches or Dia. 5 in. to 30 ft. depth gage No. 1200		
SANDY CLAY BROWN		3	5	10. Screen: Manufacturer's name SUNFLOWER PLASTICS Type RMD Dia. 5 INCH Slot/gauze 031 Length 6 FT. Set between 24 ft. and 30 ft. ft. and 30 ft. Gravel pack? NO Size range of material		
SAND FINE TAN		5	8	11. Static water level: 14 ft. below land surface Date 7/28/78		
SAND COARSE TAN		8	14	12. Pumping level below land surfaces: ft. after NA hrs. pumping NA g.p.m. ft. after NA hrs. pumping NA g.p.m. Estimated maximum yield 60 g.p.m.		
SAND GRAVEL COARSE TAN		14	20	13. Water sample submitted: NO Date		
SAND COARSE TAN		20	30	14. Well head completion: 12 inches above grade		
SAND VERY FINE GRAY		30		15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. 60 Direction SW Type LATERAL Well disinfected upon completion? NO Yes NO		
				17. Pump: Manufacturer's name NOT INSTALLED Model number NOT INSTALLED HP NOT INSTALLED Volts NOT INSTALLED Length of drop pipe NOT INSTALLED ft. capacity NOT INSTALLED g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation: 1300				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. BEARDEN RIMMELL Business name 3142 MENOR, WICHITA License No. 104 Address 3142 MENOR, WICHITA Signed OTIS W. BEARDEN Date 7/28/78 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley		19. Remarks: PACKED BOTTOM WITH 10" OF FINE SMALL ROCK				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5