

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well: <u>Sedgwick</u>		County	Fraction <u>NW SW NE SE</u> <u>NE 1/4 ME 1/4 SE 1/4</u>	Section number <u>19</u>	Township number <u>T 26 S</u>	Range number <u>R 1 E</u>
2. Distance and direction from nearest town or city: <u>4845 Bison</u> Street address of well location if in city: <u>Wichita, Ks.</u>			3. Owner of well <u>Frankberry Const.</u> R.R. or street: <u>1602 West 61st North</u> City, state, zip code: <u>Wichita, Kansas</u>			
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile			Sketch map: 6. Bore hole dia. <u>11</u> in. Completion date <u>12-1-76</u> Well depth <u>45</u> ft.			
			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
5. Type and color of material			9. Casing: Material <u>Styrene</u> Height: <u>12</u> in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <u>10</u> lbs./ft. Dia. <u>5</u> in. to <u>45</u> ft. depth Wall Thickness: inches or Dia. <u>5</u> in. to <u>45</u> ft. depth Gage No. <u>200</u>			
			10. Screen: Manufacturer's name <u>Sunflower Plastic</u> Type <u>Styrene</u> Dia. <u>5</u> in. Slot gauge <u>.06</u> Length <u>10</u> ft. Set between <u>35</u> ft. and <u>45</u> ft. Gravel pack? <u>yes</u> Size range of material <u>14-18</u> in.			
Sandy Topsoil Clay Medium Sand			11. Static water level: <u>15</u> ft. below land surface Date <u>12-1-76</u> mo./day/yr.			
			12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.			
			13. Water sample submitted: ____ Yes ____ No Date ____ mo./day/yr.			
			14. Well head completion: <u>12</u> Capped ____ Pitless adapter ____ Inches above grade			
			15. Well grouted? <u>yes</u> With: ____ Neat cement ____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>40</u> ft. to <u>14</u> ft.			
			16. Nearest source of possible contamination: <u>None</u> ft. ____ Direction ____ Type ____ Well disinfected upon completion? ____ Yes ____ No			
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: ____ Submersible ____ Turbine ____ Jet ____ Reciprocating ____ Centrifugal ____ Other			
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Harp Well Pump 236</u> Business name License No. <u>NE 53</u> Address <u>Wichita, Kansas</u> Signed <u>M. Arnold</u> Date <u>1-31-77</u> Authorized representative			
18. Elevation:		19. Remarks: <u>Flat Ground</u> <u>Septic Tank Not Installed</u> <u>when the well drilled.</u> <u>No apparent source for</u> <u>contamination.</u>		20. Water well contractor's certification:		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5