


1. Location of well: Sedgwick		County Sedgwick		Fraction NE 1/4 NE 1/4 SE 1/4		Section number 20		Township number T 26 S		Range number R 1 E	
2. Distance and direction from nearest town or city: Street address of well location if in city: 4901 North Broadway Wichita, Kansas						3. Owner of well: R. L. Harrison R.R. or street: 5030 Irving Drive City, state, zip code: Wichita, Kansas					
4. Locate with "X" in section below: Sketch map: 						6. Bore hole dia. 1 1/2 in. Completion date Well depth 45 ft. 12-17-77					
5. Type and color of material						7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary					
						8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other					
						9. Casing: Material styrene Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 12 lbs./ft. Dia. 5 in. to 45 ft. depth Wall Thickness: inches or Dia. 5 in. to 45 ft. depth gage No. 200					
						10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5 " Slot/gage .06 Length 15 ' Set between 30 ft. and 45 ft. ft. and 45 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4-1/8					
(Use a second sheet if needed)						11. Static water level: 15 ft. below land surface Date 12-17-77					
						12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.					
						13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input type="checkbox"/> No Date _____					
						14. Well head completion: 12 capped <input type="checkbox"/> Pitless adapter _____ inches above grade					
						15. Well grouted? yes 1-2 fine sand m With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 40 " ft. to 14 ft.					
						16. Nearest source of possible contamination: NONE ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
						18. Elevation:					
						19. Remarks: Flat Ground Septic System not installed at this time . No apparent source for contamination.					
						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name _____ License No. _____ Address Wichita, Kansas Signed m. Arnold Date 12-17-77 Authorized representative					