


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 820-1201-1215

Kansas Department of Health and
Environmant-Divisian of Environment
(Water well Cantrctors)
Topeka, Kansas 66620

County		Fraction	Section number	Township number	Range number
Sedgwick		NW 1/4 NE 1/4 NW 1/4	20	T 26 S	R 1E E/W
2. Distance and direction from nearest town or city:			3. Owner of well:		
Street address of well location if in city: 780 West 52nd North Wichita, Kansas			Lynn Meyer 780 West 52nd North Wichita, Kansas		
4. Locate with "X" in section below:  Sketch map:			6. Bore hole dia. 11 in. Completion date 6-15-77 Well depth 40 ft.		
			7. Cable tool X Rotary Driven Dug Hollow rod Jetted Bored Reverse rotary		
			8. Use: Domestic Public supply Industry Irrigation Air conditioning Stock X Lawn Oil field water Other		
			9. Casing: Material Styrene Height: Above or below surface 12 in. Threaded Welded Surface 12 in. RMP X PVC Weight lbs./ft. Dia. 5 in. to 40 ft. depth Wall Thickness: inches or Dia. in. to ft. depth gage No. .200		
5. Type and color of material			From	To	10. Screen: Manufacturer's name Sunflower Plastic
Topsoil			0	2	Type Styrene Dia. 5"
Clay			2	10	Slot/gauge .06 Length 20'
Fine Sand			10	17	Set between 20 ft. and 40 ft.
Medium Sand			17	40	Gravel pack? yes Size range of material 1/2-1/8"
					11. Static water level: mo./day/yr. 15 ft. below land surface Date 6-15-77
					12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.
					13. Water sample submitted: mo./day/yr. Yes No Date
					14. Well head completion: Capped Pitless adapter 12 inches above grade
					15. Well grouted? yes to 2 fine sand mix With: Neat cement Bentonite X Concrete Depth: From 40" ft. to 14 ft.
					16. Nearest source of possible contamination: Septic Tank ft. 100 Direction S.E. Type Tank Well disinfected upon completion? X Yes No
					17. Pump: X Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: Submersible Turbine Jet Reciprocating Centrifugal Other
(Use a second sheet if needed)					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name License No. Address Wichita, Kansas Signed M. Axelrod Date 8-20-77 Authorized representative
18. Elevation:		19. Remarks:			
Topography: X Hill Slope Upland Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5