


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Sedgwick	Fraction 1/4 NW 1/4 SW 1/4	Section number 21	Township number T 26 S R	Range number 1 E
2. Distance and direction from nearest town or city: Street address of well location if in city: 49th and Broadway East 1/4 mile			3. Owner of well: A. J. Mies R.R. or street: 5000 North Broadway City, state, zip code: Wichita, Kansas		
4. Locate with "X" in section below:  421 East 49th North Wichita, Kansas			6. Bore hole dia. 11 in. Completion date 8-4-76 Well depth 45 ft.		
			7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material styrene Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 45 ft. depth Wall Thickness: 200 inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 200		
5. Type and color of material			From	To	10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5" Slot/gauge 06 Length 15' Set between 30 ft. and 45 ft. Gravel pack? yes Size range of material 1-1/8"
Topsoil			0	3	11. Static water level: 16 ft. below land surface Date 8-4-76
Brown Clay			3	16	12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.
Fine Sand			16	25	13. Water sample submitted: <input type="checkbox"/> Yes <input type="checkbox"/> No Date
Medium Sand			25	44	14. Well head completion: 12 capped Pitless adapter 12 Inches above grade
Blue Shale			44	45	15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 40" ft. to 14 ft.
					16. Nearest source of possible contamination: NONE ft. Direction Type Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name License No. Address Wichita, Kansas Signed M. Arnold Date 8-19-76 Authorized representative
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			19. Remarks: Flat Ground Septic Tank not installed when well was drilled No apparent source for contamination.		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5