## WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

	County	Fraction	·			Section	number	Township number Range number
1. Location of well:	· ·		<b>377.7</b> - //	377	7. //	1		
2 Di	Sedgwick	1/4	NW 1/4	<u>א</u>			21	Ted Klaassen
2. Distance and direction from nearest town or city:  Solution 1, B1k 1 R.R. or s					er of well: street:		125 North Elm	
Street address of well location if in city:  Newton's 1st addition City, sta						Whitewater, Kansas		
4. Locate with "X" in section below:  Sketch map:							6. Bore hole dia. 11 in. Completion date  Well depth 65 ft. 10-28-77	
From 53rd North & Primrose, South 1/2,								
NW NE on the East side of the street.						Hollow rod Jetted Bored Reverse rotary		
						8. Use: X Domestic Public supply Industry		
wichita, Kansas						Irrigation Air conditioning Stock		
						Lawn Oil field water Other		
						9. Casing: Material Styrenght: Above or below Threaded Welded <u>\$1</u> Surfacein.		
						RMPX PVC Weight lbs./ft.		
I <del>&lt;</del> 1 Mile — → 1						Dia. 5 in. to 65ft, depth Wall Thickness; inches or		
5. Type and color of	material					From	То	Dia in. to ft. depth gage No
								10. Screen: Manufacturer's name Sunflower Plastic
		-				1		Type styrene Dia. 5 "
Topsoil				0	2	Slot/gauxe// 06 Length 40! Set between 25 ft. and 65 ft.		
Brown Clay					ft. andft.			
Blown Clay			2	15	Gravel pack? <u>VESSize range of moterial</u> $\frac{1}{2}-1/8!$			
Fine SAnd			15	19	11. Static water level: mo./day/yr. 20 ft. below land surfoce Date 10-28-77			
Brown Clay			19	24	12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m.			
Fine Sand				24	27	ft. after hrs. pumping g.p.m.		
Blue Shale			27	65	Estimated maximum yieldg.p.m.  13. Water sample submitted:mo./doy/yr.			
						<del>  - /</del>		Yes No Date
								14. Well head completion: capped Pitless adapter 12 Inches obove grade
			··········			<u> </u>		is well moved ves 1-2 fine sand mix i
								With: Negt cement Bentonite X Concrete
								16. Nearest source of possible contamination: NONE
								ft Direction Type Well disinfected upon completion? X Yes No
							$\vdash \vdash \vdash$	17. Pump: X Not installed
						<u> </u>	ļ	Manufacturer's name
								Model number HP Volts   Length of drop pipe ft. capacity g.p.m.
						1	$\vdash$	Type:
						Submersible Turbine		
	(Use a second sh	eet if neede	d)					Jet Reciprocating Other Other
18. Elevation: 19. Remarks:								20. Water well contractor's certification:
<b>!</b>						,	This well was drilled under my jurisdiction and this report	
Septic system not installed when the well was drilled.						•	is true to the best of my knowledge and belief.  Harp Well & PUmp 236	
Hill								Business name License No.
X Slope								Address Wichi ta, Kansas 67209
Upland Valley	No apparent source for contamination.							Signed Authorized representative / - // - 77