

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Sedgwick	Fraction 1/4 NE 1/4 NW 1/4	Section number 21	Township number T 26 S R	Range number 1E E/W
2. Distance and direction from nearest town or city: Street address of well location if in city: 1/4 South of 53rd North on Primrose.			3. Owner of well: R.R. or street: City, state, zip code:		
4. Locate with "X" in section below: N W E S 1 Mile Sketch map: Wichita, Kansas			3. Owner of well: Ted Klassen 125 North Elm Whitewater, Kansas		
5. Type and color of material			6. Bore hole dia. 11 in. Completion date 11-21-77 Well depth 60 ft.		
			7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material styrene Height: Above or below 11 ft. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 12 lbs./ft. Dia. 5 in. to 60 ft. depth Wall Thickness: inches or Dia. 5 in. to 60 ft. depth gauge No. 200		
			10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5" Slot/groove .06 Length 28' Set between 32 and 60 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4-1/8"		
			11. Static water level: 20 ft. below land surface Date 11-21-77		
			12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.		
			13. Water sample submitted: ____ mo./day/yr. Yes ____ No ____ Date ____		
			14. Well head completion: capped ____ Pitless adapter 12 Inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> yes 1-2 fine sand mix With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 40 ft. to 14 ft.		
16. Nearest source of possible contamination: NONE ft. ____ Direction ____ Type ____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ____ No ____					
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
(Use a second sheet if needed)					
18. Elevation:	19. Remarks: Flat Ground Septic System not installed at this time. No apparent source for contamination.		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name License No. Address Wichita, Kansas Signed M. Arnold Date 11-23-77 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5